

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department	Standard Components	Room Tag: 1230
Room Name	Ambulance Triage	Room Code: AMBTR
Area	12.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	Up to 3	
Also covers these Rooms		
Description/ Special Requirements	The Ambulance Triage is an area for receipt and assessment of patients arriving in the Unit by ambulance. The Ambulance Triage will be adjacent to the Ambulance entry which should include an Airlock.	
Amendment	21.02.05, - First Draft 03.03.05, - User review BOB; write-up bench added	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		Equal to Acrovyn, as required
3092	Wall protection	MDF	Laminate	Bed protection wall panel		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	optional
1110	Bench: laminate, writing	Furniture/ Fitting	1	1	ambulance write-up
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	optional
3350	Clock: battery operated	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	optional
19800	Shelf: laminate	Furniture/ Fitting	1	1	to head of trolleys
22000	Suction bottle	Furniture/ Fitting	3	2	optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department
Room Name

Standard Components
Ambulance Triage

Room Tag: 1230
Room Code: AMBTR

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	wall telephone

Services

ID	Description	Service Category	Qty	Remarks
1000	Telephone: PABX	Communications	1	wall telephone
1006	Voice / Data outlet: double	Communications	2	
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	optional
7000	Oxygen (O2)	Medical Gases	2	optional
7040	Suction	Medical Gases	2	optional
8080	Emergency call	Nurse Call	1	
8010	Staff/ Nurse assist call	Nurse Call	1	
9040	Body protected	Power		
9010	GPO: Emergency power, single	Power	2	
9000	GPO: Single	Power	2	