

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 1280
Room Name	Angiography Control/ Reporting Room	Room Code: ANCRT
Area	14.0 M2	
No of Rooms	1	
Subtotal of Area	14.0 M2	
Hours of Operation	Available 24 Hours	
Occupancy	Up to 3 staff	
Also covers these Rooms		
Description/ Special Requirements	<p>Room adjacent to Angiography Procedure Room/s with direct visibility to the patient for remote control of equipment, and review and reporting of procedure images. The Control/ Reporting room may serve two procedure rooms.</p> <p>Acoustics: Acoustic privacy is required</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> - Radiation shielding as advised by Radiation Consultant - Cable ducts from Angiography Procedure Room and Computer/Equipment room may be required 	
Amendment	<p>14.03.05, - First Draft</p> <p>20.04.05, - BOB User review, area modified</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		
9004	Doors	Solid Core/ glass	Paint	Single leaf, observation panel		910mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7025	Observation	Lead glass	Clear	Internal window		to procedure room
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	at 900H
1950	Chair: ergonomic, high	Furniture/ Fitting	3	3	
3400	Coathook	Metalwork	1	2	
17252	Pedestal drawer unit: mobile, 840mmH	Furniture/ Fitting	3	1	under bench
17360	Pinboard: fabric covered	Furniture/ Fitting	1	2	over bench
20000	Shelving unit: adjustable	Furniture/ Fitting	1	2	for books, manuals, over bench
24400	Whiteboard	Furniture/ Fitting	2	1	optional

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 1280
Room Name	Angiography Control/ Reporting Room	Room Code: ANCRT

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
11400	Computer: PC & monitor	3	1	yes	yes	—	—	—	—	—	—	
62150	IMG: console, control	1	1	yes	yes	—	—	—	—	—	—	Angiography control monitors
41100	Printer: networked	3	1	yes	yes	—	—	—	—	—	—	
54510	Telephone: handset, standard	3	2	—	yes	—	—	—	—	—	—	on bench

Services

ID	Description	Service Category	Qty	Remarks
1040	Intercom	Communications	1	with handsfree microphone to Angio room
1006	Voice / Data outlet: double	Communications	5	3 outlets under bench for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
9001	GPO: Double	Power	8	
9060	Special: for equipment	Power	1	Angiography console equipment