Australasian Standard Project

Room Data Sheets

Department **Standard Components Room Name**

Angiography Sterile Store/ Set-up

Room Tag: 1290 Room Code: ANSS

Area

No of Rooms

Subtotal of Area Hours of Operation

Occupancy Also covers these Rooms

Description/ **Special Requirements** 10.0 M2

10.0 M2 24 Hours

1 - 2 intermittently

A room for the storage and preparation of radiological media, sterile stock, medications and where set-up for Angiography procedures is undertaken. Secured staff only access to the room may be required.

Amendment

11.03.05, - First Draft

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9004	Doors	Solid Core/ glass	Paint	Single leaf, observation panel		910mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		tiles also acceptable

Fittings and Furniture (FF)

ID	escription Category		Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	
1470	Bracket: sharps	Furniture/ Fitting	2	1	
4360	Cupboard: door ht adj. shelves	Furniture/ Fitting	1	1	lockable
4410	Cupboard: under bench	Furniture/ Fitting	1	1	with adjustable shelf
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, with adjustable shelf
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12900	Louvred panel: for storage-bins	Metalwork	1	2	above bench, optional
19060	Safe: dangerous drugs, small	Furniture/ Fitting	1	1	optional
19700	Sharps bin	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3		to basin

Australasian 🕌 \mp Ğ

Provided by HPI for : **HCAMC & UNSW**

Issue No: 1 Issue Date: 4 Aug 2005

Print Date:

4 Aug 2005 Page 1 of 2

Australasian Standard Project

Room Data Sheets

Department Room Name

Standard Components

Angiography Sterile Store/ Set-up

Room Tag: 1290

Room Code: ANSS

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		refer to BHWS-B (sim)
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							optional, on bench

Services

ID	Description	Service Category	Qty	Remarks			
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone			
5000 Airconditioning		HVAC					
6000 General fluorescent		Lighting					
6055 Special: task light, built in		Lighting		under O/H cupboards			
9001	GPO: Double	Power	1				
9000	GPO: Single	Power	1	Refrigerator, under bench			
9000	GPO: Single	Power	2				