Australasian Standard Project

Room Data Sheets

Department **Standard Components** Room Tag: 1230 **Room Name** Anteroom Room Code: ANRM

Area

No of Rooms **Subtotal of Area**

Minimum Dimension Hours of Operation

> Occupancy Also covers these Rooms

Description/ **Special Requirements** 6.0 M2

6.0 M2

0.0 M2 24 Hours

1 - 2

Anteroom or airlock associated with an Isolation room for maintenance of air pressurisation and for staff and visitors to change and dispose of protective gear used on entering or exit; a staff handwashing basin will be located within the room; glazing is recommended for patient visibility. Pressurisation - negative or positive depending on type of Isolation room

Body Protected electrical area

Amendment

05.11.03, - First Draft

07.02.05, - BOB User review; fittings modified

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9115	Doors	Solid Core	Paint	1 1/2 leaf, half glazed		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
530	Basin vanity top	Furniture/ Fitting	1	1	
12300	Carrier: dirty linen, single	Furniture/ Fitting	3	1	in cupboard
3400	Coathook	Metalwork	1	4	2 inside cupboard, 2 on wall
4391	Cupboard: special	Furniture/ Fitting	1	1	with shelves & flip door for linen carrier
4350	Cupboard: tall	Furniture/ Fitting	1	1	with hooks for hanging gowns
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin

Provided by HPI for: **HCAMC & UNSW**

Print Date: 20 May 2005 Issue No: 2 Issue Date: 20 May 2005

Page 1 of 2

Australasian Standard Project

Room Data Sheets

Department Room Name

Standard Components

Anteroom

components

Room Tag: 1230
Room Code: ANRM

ID	Description	Category	Group	Qty	Selection
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection
3120	Basin: vanity	1	1			yes		yes	yes	yes	_	Type B, elbow action levers

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		