

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 1340
Room Name	Audiology Testing Room	Room Code: AUDIO
Area	14.0 M2	
No of Rooms	1	
Subtotal of Area	14.0 M2	
Hours of Operation	8am to 6pm, daily	
Occupancy	Up to 3	
Also covers these Rooms		
Description/ Special Requirements	<p>Room with an internal sound proof booth to specifications, for audiology testing. Audiometric booth should be ventilated or connected to airconditioning, power and data. Level access to the Audiometric Booth is recommended.</p> <p>Acoustics: Acoustic privacy required</p> <p>Body protected electrical area</p>	
Amendment	<p>14.03.05, - First Draft</p> <p>22.03.05, - BOB User Review; description modified</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		
9004	Doors	Solid Core/ glass	Paint	Single leaf, observation panel		910mm clear opening
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1600	Chair: child	Furniture/ Fitting	3	1	as required
1650	Chair: client	Furniture/ Fitting	3	3	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
3400	Coathook	Metalwork	1	2	
5900	Desk	Furniture/ Fitting	3	1	
17250	Pedestal drawer unit: mobile, 660mmH	Furniture/ Fitting	3	1	under desk
22780	Table: small	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
1600	Audiometric booth	3	1	yes	yes	—	—	—	—	—	—	to specification
54510	Telephone: handset, standard	3	1	—	yes	—	—	—	—	—	—	on desk

Australasian Standard Project

Room Data Sheets

Department | Standard Components
Room Name | Audiology Testing Room

Room Tag: 1340
Room Code: AUDIO

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	1 to booth, 1 outlet to desk for telephone
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6000	General fluorescent	Lighting		
9040	Body protected	Power		
9001	GPO: Double	Power	4	2- desk; 2-booth
9060	Special: for equipment	Power	1	audiometric booth
10005	Duress alarm	Security	1	