Department Standard Components Room Tag: 1490

Room Name Bay - Flowers, Enclosed Room Code: BFLW-ENC

Net Room Area Briefed 4.0 M2

No of Rooms 1

Subtotal of Briefed Area 4.00 M2

Hours of Operation 24 Hours

Occupancy 1 intermittently

Also covers these Rooms

Description/ Special Requirements An enclosed Bay for staff, relatives or visitors to fill or empty vases, and to arrange and dispose of flowers. It should include a deep sink, storage for vases and a waste bon for disposal of spent flowers. The Flower Bay will have direct access to the Unit corridor.

Acoustics: Acoustic privacy required

Amendment 31.10.03, - First Draft

15.12.08, - 2008 AUSHFG Review; description, FF & services modified

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Optional; Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Optional; Equal to 'Acrovyn'
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		Default: = vinyl, tiles also acceptable

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	open under part for bin
4410	Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelf
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to sink
6156	Dispenser: soap	Furniture/ Fitting	2	1	to sink
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	above bench for storing vases
8185	Trolley: flowers	Furniture/ Fitting	3	1	
24102	Waste bin: general	Furniture/ Fitting	3	1	under bench

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection / Remarks



Issue No: 3
Issue Date: 1 Apr 2009

Print Date: 1 Apr 2009 Page 1 of 2

Department	Standard Components	Room Tag: 1490
Room Name	Bay - Flowers, Enclosed	Room Code: BFLW-ENC

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection / Remarks
47890	Sink & drainer: single, 930mmL	1	1			yes	opt	opt	yes	yes		deep sink; short lever
												taps, provide warm water

## Services

ID	Description	Service Category	Qty	Selection / Remarks
5015	Ventilation	HVAC		
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	1	Above bench