Department Standard Components Room Tag: 1500

Room Name Bay - Handwashing, Type A Room Code: BHWS-A

Net Room Area Briefed 1.0 M2

No of Rooms 1

Subtotal of Briefed Area 1.00 M2

Minimum Dimension 1000.0 MM

Hours of Operation 24 Hours
Occupancy 1

Also covers these Rooms

Description/ Special Requirements An area which may be a recessed bay, with handwashing facilities for staff to cleanse their hands before and after every patient contact. Type A refers to a Clinical Scrub basin (Large) with wall mounted, elbow action lever taps - for surgical scrubbing.

Amendment 31.10.03, - First Draft

15.12.08, - 2008 AUSHFG Review; min dimension added, FF, FE &

services remarks added

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1045	Floor finish	Vinyl, non slip	Textured	Seamless, coved		under basin
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		Default= vinyl: tiles also acceptable
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		as required, Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	optional
6163	Dispenser: mask	Furniture/ Fitting	3	1	optional
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	
6156	Dispenser: soap	Furniture/ Fitting	2	1	
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection / Remarks
3100	Basin: scrub, Type A	1	1			yes	—	yes	yes	yes	—	wall mounted elbow

Services

ID Description Service Category	Qty Selection / Remarks
---------------------------------	-------------------------

Australasian Frovided by HPI for AHIA & UNSW for: Issue No: 3 Print Date: 1 Apr 2009

Australasian HFG Issue Date: 1 Apr 2009 Page 1 of 2

Australasian Standard Project

Room Data Sheets

Department Standard Components Room Tag: 1500

Room Name Bay - Handwashing, Type A Room Code: BHWS-A

	ID	Description	Service Category Qty		Qty Selection / Remarks		
	5000	Airconditioning	HVAC		consistent with adjacent area		
ľ	6000 General fluorescent		Lighting		consistent with adjacent area		