

Department	Standard Components	Room Tag: 1520
Room Name	Bay - Handwashing, Type C	Room Code: BHWS-C
Net Room Area Briefed	1.0 M2	
No of Rooms	1	
Subtotal of Briefed Area	1.00 M2	
Hours of Operation	24 Hours	
Occupancy	1	
Also covers these Rooms		
Description/ Special Requirements	A recessed bay off the corridor with handwashing facilities for staff to cleanse their hands before and after every patient contact. Type C refers to a Small to Medium handbasin with basin mounted lever or standard taps or a flickmixer tap- for general handwashing.	
Amendment	31.10.03, - First Draft 15.12.08, - 2008 AUSHFG Review; FF deleted, FE & services remarks added	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1045	Floor finish	Vinyl, non slip	Textured	Seamless, coved		under basin
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		Default= vinyl: tiles also acceptable
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		as required, equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	optional
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	
6156	Dispenser: soap	Furniture/ Fitting	2	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
2850	Basin: handwash, Type C	1	1	—	—	yes	—	yes	yes	yes	—	basin mounted lever or standard taps or single lever mixer tap

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		consistent with adjacent area
6000	General fluorescent	Lighting		consistent with adjacent area