

Department	Standard Components	Room Tag: 1640
Room Name	Bay - Utility, 1m2	Room Code: BUT-1
Net Room Area Briefed	1.0 M2	
No of Rooms	1	
Subtotal of Briefed Area	1.00 M2	
Hours of Operation	24 Hours	
Occupancy	1	
Also covers these Rooms		
Description/ Special Requirements	The Utility Bay provides an area with a bench and sink for use as a preparation area. The bay may be located adjacent to patient treatment areas. The bay should be located in close proximity to a staff handwashing basin.	
Amendment	01. 05.06, - First Draft 15.12.08, - 2008 AUSHFG Review; remarks added to Fabric, FF & Services amended	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		or consistent with adjacent area
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		consistent with adjacent area
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		to entire bay
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1010	Bench: stainless steel	Metalwork	1	1	with wet edge and inset sink, open under
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to sink
6156	Dispenser: soap	Furniture/ Fitting	2	1	to sink
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	under bench

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
47800	Sink, SS: single in bench	1	1	—	—	yes	opt	opt	yes	yes	—	warm water if located in a patient accessible area

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		consistent with adjacent area

Department	Standard Components	Room Tag: 1640
Room Name	Bay - Utility, 1m2	Room Code: BUT-1

ID	Description	Service Category	Qty	Selection / Remarks
6000	General fluorescent	Lighting		consistent with adjacent area