Department Standard Components Room Tag: 1660
Room Name Bay - Wheelchair Park Room Code: BWC

Net Room Area Briefed 4.0 M2

No of Rooms

Subtotal of Briefed Area 4.00 M2

Hours of Operation 24 Hours

Occupancy N/A

Also covers these Rooms

An open storage bay for wheelchairs, located in close proximity to the main

Special Requirements entrance.

Description/

Special Design Requirements: The Bay should be deep enough to ensure equipment stored does not impede corridor circulation; minimum depth

1200mm.

Amendment 24.03.05, - First Draft

15.12.08, - 2008 AUSHFG Review, FF & FE Services remarks added

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		consistent with adjacent area
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		consistent with adjacent area
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		consistent with adjacent area
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		consistent with adjacent area
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to 'Acrovyn'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		Equal to 'Acrovyn'
4022	Wall protection	Composite	Prefinished PVC	Crash rail at 350 AFFL		Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
24200	Wheelchair	Furniture/ Fitting	3	3	as required

Fixtures, Equipment and associated Services (FE)

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		consistent with adjacent area
6000	General fluorescent	Lighting		consistent with adjacent area
9001	GPO: Double	Power	1	