

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 2420
Room Name	Feeding Room	Room Code: FEED
Area	7.0 M2	
No of Rooms	1	
Subtotal of Area	7.0 M2	
Hours of Operation	24 Hours	
Occupancy	Up to 3	
Also covers these Rooms		
Description/ Special Requirements	<p>The Feeding Room provides an area for mothers to feed babies with staff assistance as required or to express breast milk. The Feeding Room will be located adjacent to the General Nursery with ready access to the Formula Room.</p> <p>Acoustics: Sound attenuation medium, acoustic protection required</p> <p>Body Protected electrical area</p>	
Amendment	23.04.2005, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9004	Doors	Solid Core/ glass	Paint	Single leaf, observation panel		910mm clear opening, lockable, obs panel to Formula Rm side only
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
350	Artwork	Furniture/ Fitting	3	1	optional
2000	Chair: lounge	Furniture/ Fitting	3	2	
2655	Chair: visitor	Furniture/ Fitting	3	1	
3400	Coathook	Metalwork	1	1	
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door
22800	Table: low	Furniture/ Fitting	3	2	

Fixtures, Equipment and associated Services (FE)

Australasian Standard Project
Room Data Sheets

Department	Standard Components	Room Tag: 2420
Room Name	Feeding Room	Room Code: FEED

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6000	General fluorescent	Lighting		
9040	Body protected	Power		
9000	GPO: Single	Power	4	