# **Australasian Standard Project**

**Room Data Sheets** 

Department **Room Name** 

**Standard Components** 

Interview Room - Family/ Large

Room Tag: 2080 Room Code: INTF

Area

No of Rooms **Subtotal of Area** 

**Minimum Dimension** 

**Hours of Operation** Occupancy

Also covers these Rooms

Description/ **Special Requirements**  12.0 M2

12.0 M2 0.0 M2

24 Hours

Up to 6 persons

A larger Interview Room to undertake confidential discussion and/ or counselling between staff, patients and or family members where required. The Interview Room may also be used as a multipurpose room for small staff groups or discussions. An external outlook is desirable. The Interview Room - Family may also be used for mental health patients.

If used for this purpose an observation window (toughened glass with integral venetians) should be installed.

Acoustics: Sound attenuation level - high; Acoustic privacy required.

Additional Design Considerations:

- A second egress door may be required for staff safety and security

**Amendment** 

20.11.03, - First Draft

08.02.05, - BOB User review, window added for mental health use

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, lock set
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.		Vinyl also acceptable
7032	Observation	Steel/ Toughened glass	Paint	Internal window		double glazing for mental health use
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH		or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable			
7001	Windows					Desirable

#### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection	
350	Artwork	Furniture/ Fitting	3	1	optional	
1250	Blind: Venetian	Metalwork	3	1	if windows provided	
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	for mental health use	
2655	Chair: visitor	Furniture/ Fitting	3	6		
17385	Pinboard/ whiteboard combination	Furniture/ Fitting	1	1	optional	



Provided by HPI for:

Issue No: 2 Issue Date: 20 May 2005

Print Date: 20 May 2005

Page 1 of 2

# **Australasian Standard Project**

### **Room Data Sheets**

Department Room Name

Standard Components
Interview Room - Family/ Large

Room Tag: 2080
Room Code: INTF

ID	Description	Category	Group	Qty	Selection
22800	Table: low	Furniture/ Fitting	3	2	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection
54510	Telephone: handset, standard	3	1		yes							on table

### Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6046	Indirect lighting	Lighting		optional
9001	GPO: Double	Power	3	
10005	Duress alarm	Security	1	