Department Standard Components Room Tag: 2800

Room Name Lounge - Patient, 10m2 Room Code: LNPT-10

Net Room Area Briefed 10.0 M2

No of Rooms

Subtotal of Briefed Area 10.00 M2

Hours of Operation 24 Hours

Occupancy

Also covers these Rooms

Description/
Special Requirements

The Patient Lounge provides a change of environment away from clinical areas for patients and visitors. It is an area where family groups can visit and patients can socialise. An external outlook is essential.

Up to 6 patients/ visitors; 1-2 staff intermittently

Access for patient lifter and bed may be required.

Acoustics: Sound attenuation level - Medium; Acoustic privacy required.

Body Protected electrical area

Amendment 16.05.05, - First Draft

15.12.08, - 2008 AUSHFG Review; fabric amended, furnishings amended,

description amended, services amended

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9115	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, half glazed		910mm/ 1400mm clear opening, small door leaf optional
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		Default = carpet; vinyl also acceptable
7035	Observation	Alum/ Glass	Powdercoat	Internal window		optional
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH		Default = feather edged: or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable			
7001	Windows					essential

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
350	Artwork	Furniture/ Fitting	3	2	optional
23410	Bracket: television, wall mount Metalwork		1	1	optional
2150	Chair: patient	Furniture/ Fitting	3	4	adjustable height may be required
2650	Chair: visitor, patient	Furniture/ Fitting	3	2	
4900	Curtain track: window	Metalwork	1	1	
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	or blinds
22800	Table: low	Furniture/ Fitting	3	2	

Australasian FG Provided by HPI for AHIA & UNSW for :

Issue No: 3
Issue Date: 1 Apr 2009

Print Date:

1 Apr 2009 Page 1 of 2 Department Room Name

Standard Components Lounge - Patient, 10m2 Room Tag: 2800

Room Code: LNPT-10

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	1		yes							optional, on table
54550	Television: 34 cm	3	1	yes								optional, on bracket, flat

Services

ID	Description	Service Category	Qty	Selection / Remarks		
1090	TV: MATV	Communications	1	optional		
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone		
5000 Airconditioning		HVAC				
6000	General fluorescent	Lighting				
6046	Indirect lighting	Lighting		optional		
8080	Emergency call	Nurse Call	1	+ indicator button & light		
8005	Patient call handset	Nurse Call	1	+ indicator button & light		
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light		
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light		
9040	Body protected	Power				
9015	GPO: Cleaner	Power	1	as required		
9000	GPO: Single	Power	4			
9060	GPO: Special: for equipment	Power	1	TV, optional		