## **Australasian HFG Standard Components**

Milestone: Default **Room Data Sheets** 

> Department **Standard Components Room Name Mortuary - Autopsy Room**

Room Tag: 3030 Room Code: MOR-AU

Area

30.0 M2

No of Rooms

**Subtotal of Area** 

30.0 M2

**Hours of Operation** 

Available 24 Hours

Occupancy

Up to 4

Also covers these

**Special Requirements** 

Rooms

Description/

Room for undertaking post mortem examinations. The Autopsy Room should be located adjacent to the Body Cool Store and have ready access to a clean-up area.

Additional Design Considerations

- Doors to be sealed for odours
- Post mortem table to have water flushing system
- An observation area is optional

**Amendment** 

14.03.05, - First Draft

20.04.05, - BOB User review, table & fittings modified

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		observation window/s
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		

#### Fittings and Furniture (FF)

Description	Category	Group	Qty	Selection
Bench: stainless steel	Metalwork	1	1	with wet edge & draining sink
Bracket: sharps	tet: sharps Furniture/ Fitting		1	
Cabinet: instrument	Furniture/ Fitting	3	1	
Clock: battery operated	Furniture/ Fitting	3	1	
Dispenser: disposable glove	Furniture/ Fitting	2	1	
Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
Dispenser: soap	Furniture/ Fitting	2	1	to basin
	Bench: stainless steel Bracket: sharps Cabinet: instrument Clock: battery operated Dispenser: disposable glove Dispenser: paper/ hand towel	Bench: stainless steel Metalwork  Bracket: sharps Furniture/ Fitting  Cabinet: instrument Furniture/ Fitting  Clock: battery operated Furniture/ Fitting  Dispenser: disposable glove Furniture/ Fitting  Dispenser: paper/ hand towel Furniture/ Fitting	Bench: stainless steel Metalwork 1  Bracket: sharps Furniture/ Fitting 2  Cabinet: instrument Furniture/ Fitting 3  Clock: battery operated Furniture/ Fitting 3  Dispenser: disposable glove Furniture/ Fitting 2  Dispenser: paper/ hand towel Furniture/ Fitting 2	Bench: stainless steel Metalwork 1 1  Bracket: sharps Furniture/ Fitting 2 1  Cabinet: instrument Furniture/ Fitting 3 1  Clock: battery operated Furniture/ Fitting 3 1  Dispenser: disposable glove Furniture/ Fitting 2 1  Dispenser: paper/ hand towel Furniture/ Fitting 2 1



Issue No: 1 Issue Date: 8 Jun 2007 Print Date:

8 Jun 2007 Page 1 of 2

# **Australasian HFG Standard Components**

Milestone: Default Room Data Sheets

Department Room Name

Standard Components

Mortuary - Autopsy Room

Room Tag: 3030

Room Code: MOR-AU

ID	Description	Category	Group	Qty	Selection
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
19700	Sharps bin	Furniture/ Fitting	3	1	
19820	Shelf: SS, under	Metalwork	1	1	under SS bench
21730	Stool: operating, mobile	Furniture/ Fitting	3	1	
21950	Suction adapter	Furniture/ Fitting	3	1	to table
23950	Trolley	Furniture/ Fitting	3	1	
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin
24400	Whiteboard	Furniture/ Fitting	1	1	900x900, optional

# Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection
3100	Basin: scrub, Type A	1	1	_		yes		yes	yes	yes	_	refer to BHWS-A (sim); sensor taps
45600	Hose reel: retractable	1	1			yes			yes			
32150	Light: procedure, ceiling	1	1	yes								
53050	Saw: surgical	3	1	yes								
47800	Sink, SS: single in bench	1	1			yes	opt	opt	yes	yes		sensor taps, hot water
49205	Sink: draining	1	1			yes	yes		yes	yes		in bench, sensor taps, hot water
54100	Table: post mortem	1	1	yes		yes	yes		yes	yes	—	& medical gases to pedestal
54520	Telephone: handset, handsfree	3	1		yes							wall telephone
68700	Xray viewer: 2 screen	1	1	yes								recessed

### Services

ID	Description	Service Category	Qty	Remarks
1040	Intercom	Communications	1	
1000	Telephone: PABX	Communications	1	wall phone, handsfree
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	2	1 under sink, with removable filtered trap
6001	General: colour corrected	Lighting		
7040	Suction	Medical Gases	1	to table
7030	Tool Air	Medical Gases	1	to table
9001	GPO: Double	Power	1	
9010	GPO: Emergency power, single	Power	2	1-table; 1-bench
9000	GPO: Single	Power	5	2-table; 2-bench; 1-wall