Department	Standard Components	**Room Tag:**	3060
Room Name	Mortuary - Exit	**Room Code:**	MOR-EX

Area	7.0 M2
No of Rooms	1
Subtotal of Area	7.0 M2
Hours of Operation	24 Hours
Occupancy	1 - 2 intermittently
Also covers these Rooms	
Description/ Special Requirements	Exit from Mortuary Cool Store area to the loading dock area. Entry to this area by authorised personnel. Handwashing facilities should be located inclose proximit. This area may include a obsevation bay for Autospy room if required.
Amendment	21.03.05, - First Draft
20.04.05, - BOB User review, observation window & workstation added

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5030	Ceiling	Plasterboard	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		Equal to 'Acrovyn', as required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	to desk, if provided
3400	Coathook	Metalwork	1	2	
5900	Desk	Furniture/ Fitting	3	1	optional, small
17360	Pinboard: fabric covered	Furniture/ Fitting	1	1	900 x 900, optional

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	to desk, optional

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone

Australasian **HFG**

Provided by CHAA for :
Australasian HFG

Issue No: 1
Issue Date: 8 Jun 2007

Print Date: 8 Jun 2007
Page 1 of 2

This document is for advisory purpose only

Department	Standard Components	Room Tag:	3060
Room Name	Mortuary - Exit	Room Code:	MOR-EX

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	2	

Australasian HFG

Provided by CHAA for :
Australasian HFG

Issue No: 1

Issue Date: 8 Jun 2007

Print Date: 8 Jun 2007

Page 2 of 2

This document is for advisory purpose only