Australasian Standard Project
Room Data Sheets

Department	Standard Components	**Room Tag:**	3070
Room Name	Mortuary - Viewing Room	**Room Code:**	MOR-VR

Area	8.0 M2
No of Rooms	1
Subtotal of Area	8.0 M2
Hours of Operation	24 Hours
Occupancy	1 trolley; Up to 3 family members; 1 staff member intermittently
Also covers these Rooms	
Description/ Special Requirements	The Viewing Room is provided for bodies to be viewed by relatives/ friends. Bodies may be viewed through a window and optional access may be provided for relatives to directly view bodies. The Viewing Room will be located adjacent to the Mortuary Waiting Area.
Amendment	14.03.05, - First Draft 21.03.05, - BOB User review, doors modified

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9210	Doors	Solid Core	Paint	Double leaf		1600mm clear opening, to Cool Store area, lockable, optional
9002	Doors	Solid Core/ Glass	Paint	Single leaf, half glazed		910mm clear opening, from Waiting area, optional, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		viewing window
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		Equal to 'Acrovyn', not required if room enclosed with walls & doors

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
4700	Curtain track: privacy screen	Metalwork	1	1	to bay & viewing window
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	
15460	Trolley: mortuary, hydraulic	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

Australasian **HFG**

Provided by HPI for :
HCAMC

Issue No: 2
Issue Date: 23 May 2006

Print Date: 23 May 2006
Page 1 of 2

This document is for advisory purpose only

Department	**Standard Components**	**Room Tag:**	**3070**
Room Name	**Mortuary - Viewing Room**	**Room Code:**	**MOR-VR**

Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
6000	General fluorescent	Lighting		

Provided by HPI for :

HCAMC

Issue No: 2

Issue Date: 23 May 2006

Print Date: 23 May 2006

Page 2 of 2

This document is for advisory purpose only