

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department	Standard Components	Room Tag: 3400
Room Name	Patient Bay - Critical, 20m2	Room Code: PBC-20
Area	20.0 M2	
No of Rooms	1	
Subtotal of Area	20.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 patient, 1-2 visitors, Up to 6-8 staff	
Also covers these Rooms		
Description/ Special Requirements	A Single Bed Bay for patient requiring critical care nursing and medical treatment; Visual access to Staff Station is required; Screen curtains are required for patient privacy. Maximum natural light is required to patient beds. Acoustics: Acoustic privacy is required. Cardiac Protected Electrical Area	
Amendment	24.01.05, - First Draft 01.03.05, - BOB User review, fittings modified	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7055	Observation	Alum/ Glass	Powdercoat	Internal window, double glazed		to partition walls, with integral Venetians
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, tiles also acceptable
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		Equal to 'Acrovyn'
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
7001	Windows					desirable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	4	
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	to each window, controls to both sides
1480	Bracket: ECG monitor	Furniture/ Fitting	3	1	mounted on pendant
1470	Bracket: sharps	Furniture/ Fitting	3	1	mounted to trolley
23400	Bracket: television, ceiling	Metalwork	1	1	
2200	Chair: recliner	Furniture/ Fitting	3	1	patient - intermittent use; may be stored when not in use
2610	Chair: visitor, stackable	Furniture/ Fitting	3	1	

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department
Room Name

Standard Components
Patient Bay - Critical, 20m2

Room Tag: 3400
Room Code: PBC-20

ID	Description	Category	Group	Qty	Selection
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
8070	Flowchart stand: mobile	Furniture/ Fitting	3	1	
12300	Linen carrier: dirty, single	Furniture/ Fitting	3	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	4	
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
21700	Stool: adjustable, mobile, high	Furniture/ Fitting	3	1	for staff
22000	Suction bottle	Furniture/ Fitting	3	4	
22050	Suction bottle carrier	Furniture/ Fitting	3	1	mobile
16200	Table: overbed	Furniture/ Fitting	3	1	
23950	Trolley	Furniture/ Fitting	3	1	
24125	Waste bin: clinical	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin
24400	Whiteboard	Furniture/ Fitting	2	1	600mm x 600mm

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3100	Basin: scrub, Type A	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-A (sim)
3730	Bed: ICU, electric	3	1	yes	___	___	___	___	___	___	___	
9700	Clock: analogue, electric	1	1	yes	___	___	___	___	___	___	___	ceiling mounted, master clock system
15985	Dialysis station	1	1	___	___	yes	___	yes	yes	yes	___	with Reverse Osmosis (RO) water & tundish drain
32150	Light: procedure, ceiling	1	1	yes	___	___	___	___	___	___	___	
36050	Monitor: cardiac	3	1	yes	opt	___	___	___	___	___	___	
47020	Services pendant: 2 arm, height adj	1	1	yes	yes	___	___	___	___	___	___	
54520	Telephone: handset, handsfree	3	1	___	yes	___	___	___	___	___	___	to staff work area
54550	Television: 34 cm	3	1	yes	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Remarks
1120	Monitor connection facilities and cabling	Communications	1	to services pendant
1090	TV: MATV	Communications	1	
1006	Voice / Data outlet: double	Communications	2	1-ceiling services box, 1-wall; 1 outlet on each panel for telephone
1006	Voice / Data outlet: double	Communications	1	services pendant
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6060	Special: night lights	Lighting		
7020	Medical Air (MA)	Medical Gases	2	to services pendant
7000	Oxygen (O2)	Medical Gases	4	to services pendant
7040	Suction	Medical Gases	4	to services pendant

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department
Room Name

Standard Components
Patient Bay - Critical, 20m2

Room Tag: 3400
Room Code: PBC-20

ID	Description	Service Category	Qty	Remarks
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9030	Cardiac protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	2	to walls
9001	GPO: Double	Power	2	to ceiling mounted services/data box
9011	GPO: Emergency power, double	Power	1	to dialysis station
9010	GPO: Emergency power, single	Power	12	to services pendant
9000	GPO: Single	Power	12	to services pendant
9060	GPO: Special: for equipment	Power	3	TV, proc light, clock
11050	Column	Services Panels	1	for power/ data, ceiling suspended, as required to flowchart area