

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 3490
Room Name	Patient Bay - Recovery, Stage 1	Room Code: PBTR-RS1
Area	9.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 patient; 1 staff	
Also covers these Rooms		
Description/ Special Requirements	<p>A Patient Bed Bay used for the recovery of patients from anaesthetic, located within the Operating Unit or Day Procedures Unit. A clinical handwashing basin will be provided for each 4 Recovery Bed Bays. Recovery Bed Bays will require direct observation from the Staff Station.</p> <p>Cardiac Protected electrical area</p>	
Amendment	<p>24.01.05, - First Draft</p> <p>22.03.05, - BOB User review, fittings modified, louvred panel deleted</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
7001	Windows					Desirable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	
700	Bed: inpatient, manual	Furniture/ Fitting	3	1	
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	to external window/s
15100	Bracket: monitor	Furniture/ Fitting	3	1	
1470	Bracket: sharps	Furniture/ Fitting	2	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
12900	Louvred panel: for storage-bins	Metalwork	1	1	optional
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
19700	Sharps bin	Furniture/ Fitting	3	1	
19800	Shelf: laminate	Furniture/ Fitting	1	1	to bedhead, full length
21755	Storage bins	Furniture/ Fitting	3	3	to louvred panel, if provided

Australasian Standard Project

Room Data Sheets

Department **Standard Components**
Room Name **Patient Bay - Recovery, Stage 1**

Room Tag: **3490**
Room Code: **PBTR-RS1**

ID	Description	Category	Group	Qty	Selection
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
31700	Light: examination, ceiling	1	1	yes	—	—	—	—	—	—	—	
36050	Monitor: cardiac	3	1	yes	opt	—	—	—	—	—	—	on bracket

Services

ID	Description	Service Category	Qty	Remarks
1120	Monitor connection facilities and cabling	Communications	1	optional, if networked monitoring required
1006	Voice / Data outlet: double	Communications	1	services panel
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	services panel
7000	Oxygen (O2)	Medical Gases	2	services panel
7040	Suction	Medical Gases	2	services panel
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9030	Cardiac protected	Power		
9015	GPO: Cleaner	Power	1	may serve a group of beds
9010	GPO: Emergency power, single	Power	4	3-services panel, 1 for monitor, if required
9000	GPO: Single	Power	3	services panel
9060	Special: for equipment	Power	1	exam light
11000	Wall panel	Services Panels	1	