Australasian Standard Project

Room Data Sheets

Department Standard Components

12.0 M2

12.0 M2

24 Hours Up to 3

Preparation Room - Non Sterile (Pharmacy)

Room Tag: 3620

Room Code: PREP

Area

No of Rooms

Room Name

Subtotal of Area Hours of Operation

Occupancy

Also covers these Rooms

Description/ Special Requirements The Preparation Room provides a wet area for cleaning of equipment and extemporaneous preparation and compounding of medications as required. The Preparation area should be located in close proximity to the Assembly/ Preparation area.

Amendment

14.03.05, - First Draft

21.03.05, - BOB User review, bench modified

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		Equal to 'Acrovyn'; as required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	
4420	Cupboard: under bench, lockable	Furniture/ Fitting	1	1	adjustable shelves
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelves
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	2	to sink & handbasin
6156	Dispenser: soap	Furniture/ Fitting	2	2	to sink & handbasin
23950	Trolley	Furniture/ Fitting	3	2	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description		Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection
2800	Basin: handwash, Type B		1	_		yes		yes	yes	yes		refer to BHWS-B (sim)
48100	Sink & drainer: R bowl, 930mmL	1	1	_		yes	opt	opt	yes	yes		hot water
54510	Telephone: handset, standard	3	1		yes							to bench, optional

Services

ID	Description		Service Category	Qty	Remarks			
1006	Voice / Data outlet: double		Communications	1	1 outlet for telephone			
Australasian 🚾 🛅 😭		Provided by HPI fo	ovided by HPI for :		Issue No: 1	Print Date:	4 Aug 2005	
		HCAMC		ı	ssue Date: 4 Aug 200	5	Page 1 of 2	

Australasian Standard Project

Room Data Sheets

Department Standard Components Room Tag: 3620

Room Name Preparation Room - Non Sterile (Pharmacy) Room Code: PREP

ID	Description	Service Category		Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
9001	GPO: Double	Power	3	