

| | | |
|--|---|---------------------------|
| Department | Standard Components | Room Tag: 3640 |
| Room Name | Procedure Room, 16m2 | Room Code: PROC-16 |
| Net Room Area Briefed | 16.0 M2 | |
| No of Rooms | 1 | |
| Subtotal of Briefed Area | 16.00 M2 | |
| Hours of Operation | 24 Hours | |
| Occupancy | 1 patient; 2 - 4 staff | |
| Also covers these Rooms | | |
| Description/ Special Requirements | <p>The Procedure Room may be provided for the performance of procedures that do not require the full facilities of the Operating Suite. This may include suturing or wounds, complex dressings, lumbar puncture, catheterisations, administration of local anaesthesia and use of medical gases in connection with the procedures being performed. General anaesthesia will not be administered in this room.</p> <p>Cardiac Protected electrical area</p> <p>Acoustics: Sound attenuation level - Medium. Acoustic privacy required.</p> | |
| Amendment | <p>07.06.05, - First Draft 10.03.09, - 2009 AUSHFG review; size modified to 16m2; Description, FF, FE & Services modified</p> | |

Room Fabric and outline specifications

| ID | Fabric | Material | Finish | Specification | Selection | Remarks |
|------|-----------------|-------------------|-------------------------|--------------------------------|-----------|---|
| 5010 | Ceiling | Plasterboard | Paint, washable | Flush set, suspended | | |
| 6030 | Cornice | Aluminium | Powdercoat | 24mm shadow angle | | |
| 8010 | Door protection | Composite | Prefinished PVC | Protection plate to 900 AFFL | | Equal to 'Acrovyn' |
| 8040 | Door protection | Composite | Prefinished PVC | To door frame | | Equal to 'Acrovyn' |
| 9125 | Doors | Solid Core/ Glass | Paint | 1 1/2 leaf, observation panel | | 1400mm clear opening, cover to glazing |
| 9004 | Doors | Solid Core/ Glass | Paint | Single leaf, observation panel | | 910mm clear opening, optional door to Clean Utility |
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, coved | | |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150 mmH | | |
| 3000 | Wall finish | Paint | Acrylic, washable | | | |
| 3052 | Wall finish | Vinyl | Prefinished | Wall vinyl to 1500 AFFL | | |
| 3092 | Wall protection | MDF | Laminate | Bed protection wall panel | | |

Fittings and Furniture (FF)

| ID | Description | Category | Group | Qty | Selection / Remarks |
|------|-----------------|--------------------|-------|-----|---------------------|
| 150 | Air flowmeter | Furniture/ Fitting | 3 | 1 | |
| 1050 | Bench: laminate | Furniture/ Fitting | 1 | 1 | optional |
| 1470 | Bracket: sharps | Furniture/ Fitting | 2 | 1 | |

Department **Standard Components**
 Room Name **Procedure Room, 16m2**

Room Tag: **3640**
 Room Code: **PROC-16**

| ID | Description | Category | Group | Qty | Selection / Remarks |
|-------|----------------------------------|--------------------|-------|-----|--|
| 1465 | Bracket: suction bottle | Furniture/ Fitting | 2 | 2 | |
| 4420 | Cupboard: under bench, lockable | Furniture/ Fitting | 1 | 1 | optional; adjustable shelves |
| 4470 | Cupboard: wall mounted, lockable | Furniture/ Fitting | 1 | 1 | optional; over bench, adjustable shelves |
| 4600 | Curtain track: bed screen | Metalwork | 1 | 1 | to door opening |
| 5000 | Curtain: bed screen | Furniture/ Fitting | 3 | 1 | |
| 6152 | Dispenser: disposable glove | Furniture/ Fitting | 2 | 1 | |
| 6154 | Dispenser: paper/ hand towel | Furniture/ Fitting | 2 | 1 | to basin |
| 6156 | Dispenser: soap | Furniture/ Fitting | 2 | 1 | to basin |
| 6158 | Dispenser: soap antiseptic | Furniture/ Fitting | 2 | 1 | to basin |
| 16250 | Oxygen flowmeter | Furniture/ Fitting | 3 | 2 | |
| 19700 | Sharps bin | Furniture/ Fitting | 3 | 1 | wall mounted |
| 15150 | Shelf: monitor | Furniture/ Fitting | 1 | 1 | or bracket, optional |
| 21950 | Suction adapter | Furniture/ Fitting | 3 | 2 | |
| 22000 | Suction bottle | Furniture/ Fitting | 3 | 2 | |
| 23950 | Trolley | Furniture/ Fitting | 3 | 1 | instrument / procedure |
| 24100 | Waste bin: paper, 20 Litre | Furniture/ Fitting | 3 | 1 | to basin |

Fixtures, Equipment and associated Services (FE)

| ID | Description | Group | Qty | Ele | Data | CdW | HtW | WmW | Tap | Dns | Gas | Selection / Remarks |
|-------|--------------------------------------|-------|-----|-----|------|-----|-----|-----|-----|-----|-----|-----------------------|
| 3100 | Basin: scrub, Type A | 1 | 1 | ___ | ___ | yes | ___ | yes | yes | yes | ___ | refer to BHWS-A (sim) |
| 3700 | Bed: inpatient, electric | 3 | | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | space required only |
| 9700 | Clock: analogue, electric | 1 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | |
| 32150 | Light: procedure, ceiling | 1 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | |
| 36055 | Monitor: cardiac with vital signs | 3 | 1 | yes | opt | ___ | ___ | ___ | ___ | ___ | ___ | optional |
| 43800 | Refrigerator: under-bench, 120 Litre | 3 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | optional |
| 54520 | Telephone: handset, handsfree | 3 | 1 | ___ | yes | ___ | ___ | ___ | ___ | ___ | ___ | |
| 68700 | Xray viewer: 2 screen | 1 | 1 | yes | ___ | ___ | ___ | ___ | ___ | ___ | ___ | recessed |

Services

| ID | Description | Service Category | Qty | Selection / Remarks |
|------|---|------------------|-----|---|
| 1120 | Monitor connection facilities and cabling | Communications | 1 | |
| 1006 | Voice / Data outlet: double | Communications | 2 | 1 outlet for telephone |
| 5000 | Airconditioning | HVAC | | |
| 6001 | General: colour corrected | Lighting | | |
| 7020 | Medical Air (MA) | Medical Gases | 1 | |
| 7010 | Nitrous Oxide (N2O) | Medical Gases | 1 | optional |
| 7000 | Oxygen (O2) | Medical Gases | 2 | |
| 7070 | Scavenge | Medical Gases | 1 | if N2O provided |
| 7040 | Suction | Medical Gases | 2 | |
| 8080 | Emergency call | Nurse Call | 1 | + indicator button & light |
| 8005 | Patient call handset | Nurse Call | 1 | call button & light switch on the handset |
| 8000 | Patient/ Staff call | Nurse Call | 1 | + indicator button & light |
| 8010 | Staff/ Nurse assist call | Nurse Call | 1 | + indicator button & light |
| 9030 | Cardiac protected | Power | | |
| 9001 | GPO: Double | Power | 2 | |

Department | **Standard Components**
Room Name | **Procedure Room, 16m2**

Room Tag: 3640
Room Code: PROC-16

| ID | Description | Service Category | Qty | Selection / Remarks |
|-------|------------------------------|------------------|-----|-------------------------------|
| 9010 | GPO: Emergency power, single | Power | 4 | services panel, 1 for monitor |
| 9000 | GPO: Single | Power | 3 | services panel |
| 9060 | GPO: Special: for equipment | Power | 4 | clock, XRV, light, fridge |
| 11000 | Wall panel | Services Panels | 1 | |