



1 Bed Room - CCU

Room Code	1BR-CCU
Briefed Area	20.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 visitors; up to 4 staff intermittently
Hours of Operation	24 hours

Description | A 1 Bed Room - CCU will accommodate one patient and support the delivery of a range of clinical care, minor procedures and diagnostic tests, with clinical staff requiring access to both sides of the bed.

Electrical | PROTECTION: body protected ☐
PROTECTION: cardiac protected ☒

Lighting | LIGHTING: general ☐
LIGHTING: colour corrected ☒
LIGHTING: dimmable ☐
LIGHTING: indirect ☐

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset ☒

HVAC | AIRCONDITIONING: general ☒
AIRCONDITIONING: HEPA filtered ☐
AIRCONDITIONING: positive pressure ☐
AIRCONDITIONING: negative pressure ☐
VENTILATION: exhaust ☐
VENTILATION: natural ☐

Additional Considerations

- 1 Bed Room - CCU may vary in configuration to suit different Ensuite options including inboard, outboard and stacked (also known as 'back-to-back' or 'nested') configurations. In each configuration, sufficient clearance is required for equipment and staff to access both sides of the bed.
- Glazed doors and observation windows may be provided for visibility of high acuity patients and monitoring equipment. The provision of observation windows and the use of interstitial blinds or privacy curtains is to be supported by operational models for observation as well as support for patient privacy.
- The configuration of the Medical Services Panel (MSP), including medical gases, power and data, will be dependent on service requirements. Data provision is to take into consideration the increasing demand and sophistication of information systems and the technological development of monitoring and diagnostic equipment.
- Natural light and outlook is essential and the patient will need to have an external outlook from either the chair or the bed, preferably both.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel	[DWGL-033] to corridor; extent of glazing to suit service requirements
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] to ensuite
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to ensuite side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to bedroom side
WIFX-008.01	WINDOW: fixed, internal, single glazed, sill at 1050H	[DWOB-001] optional; extent of glazing to suit service requirements

CODE	DESCRIPTION	COMMENT
WIFX-155.01	WINDOW: fixed, external, double glazed, sill at 600H	[DWWH-005] external, natural light and outlook essential
AHWCV-001	WINDOW COVERING: blind, roller, single	[DWWD-004]



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-101	SPLASHBACK: vinyl	[WLWA-010] to basin
CLFS-011	CEILING: flush set, suspended	[CLFS-006] ceiling tiles may also be acceptable dependent upon the acuity of patients to be accommodated and procedures to be performed within the room
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]
WLPR-001	WALL PROTECTION: bedhead wall panel, full height	[WLPR-002]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOCU-413	WARDROBE: built-in, single door, fixed shelves, clothing rail	①	1	[FIJO-209] type and extent of storage for patient property to suit operational policies



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-101	BRACKET: suction bottle, wall mounted	②	2	[FIHR-019]
FIHR-111	BRACKET: sharps bin, wall mounted	②	1	[FIHR-016] optional, mobile sharps bin may be provided to be shared between multiple rooms
FIHR-214	BRACKET: computer display screen, single, articulated, ceiling mounted	②	1	[FIHR-004] to patient entertainment screen; configuration will be dependent on operational and ICT policies
FIHR-411	BRACKET: patient monitor, articulated, wall mounted	②	1	[FIHR-067]
FIRT-051	TRACK: curtain, privacy	①	1	[FIRT-047] to door and observation window
FQBS-101	CHAIR: visitor, clinical areas	③	1	[FQBS-030]
FQGE-101	CURTAIN: privacy screen	③	1	[FQGE-010] to door and observation window
FQSN-101	BEDSIDE TABLE: floor standing, patient locker	③	1	[FQSN-051] type and extent of storage for patient property to suit operational policies
FQTA-091	TABLE: overbed, mobile, height adjustable	③	1	[FQTA-013] z

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQWS-003	BIN: sharps, clinical, medium	③	1	[FQCW-044] optional, mobile sharps bin may be provided to be shared between multiple rooms
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin
HYBA-121	BASIN: type B, handwashing	①	1	[HYBA-010]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037] to basin
ITCL-301	DISPLAY SCREEN: patient entertainment system	②	1	[ITBU-012] configuration will be dependent on operational and ICT policies
ITNE-071	TELEPHONE: handset, desktop	③	1	[ITNE-049] optional, to patient locker; provision dependent on operational policies
MMBE-101	BED: patient, electric, with mattress	③	1	[MMBE-010]
MMGE-019	CHAIR: patient	③	1	[MMGE-019]
MMGE-191	CANNISTER: suction bottle	③	2	[MMGE-100]
MMPM-021	MONITOR: patient, high acuity	③	1	[MMHA-005] telemetry provision to suit service requirements



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101.01	GPO: single, wall mounted, horizontal	①	1	[ELGP-109] to bedhead; low level for electric bed
ELGP-101.01	GPO: single, wall mounted, horizontal	①	1	[ELGP-109] adjacent to patient chair
ELGP-105	GPO: single, wall mounted, cleaner	①	1	[ELGP-110]
ELGP-106.01	GPO: single, ceiling mounted, horizontal	①	1	[ELGP-101] to patient entertainment system
ELGP-231.01	GPO: double, emergency power, wall mounted, horizontal	①	1	[ELGP-223] to patient monitor
ELPR-051	PANEL: equipotential (EP) test point, wall mounted	①	1	[ELBO-005]
ELPR-071	RCD: residual current device, wall mounted	①	3	[ELPR-006] on services panel
ELSW-001	SWITCH: light	①	3	[ELBO-015] 1 to general room lighting, 1 to night lighting, 1 on services panel to reading light
HYDR-201	DIRECT CONNECTION: wastewater, general	①	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	①	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	①	1	to basin tapware
ITCL-121	BUTTON: nurse call, patient to staff call, with cancel, wall mounted	①	1	[ITCL-006] on services panel, with indicator button and light
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	①	1	[ITCL-008] on services panel, with indicator button and light
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	①	1	[ITCL-004] above services panel, with indicator button and light
ITCL-251	HANDSET: nurse call, patient to staff call	①	1	[ITCL-028] on services panel
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	1	[ITIN-026] to patient monitor
ITIN-071	OUTLET: MATV, ceiling mounted	①	1	[ITIN-070] to patient entertainment screen, may be replaced with data outlet in accordance with ICT policy
LIFX-151	LIGHT: night, wall mounted	①	1	[LIFX-017] switch to patient handset and wall near entry
LIFX-161	LIGHT: reading, wall mounted	①	1	[LIFX-011] switch to patient handset and services panel



Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	1	1	[MMSP-026]
ELGP-146	GPO: single, emergency power, on services panel	1	9	[ELGP-122] type and quantity to suit service requirements
ITIN-025	OUTLET: data, double RJ45, on services panel	1	2	[ITIN-025] quantity to suit service requirements
MGAS-022	OUTLET: medical air, on services panel	1	1	[MGAS-022]
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	[MGAS-042]
MGAS-062	OUTLET: suction, on services panel	1	2	[MGAS-062]
MGFP-021	FLOWMETER: medical air	3	1	[MGFP-002]
MGFP-041	FLOWMETER: oxygen	3	2	[MGFP-004]
MGFP-061	ADAPTER: suction	3	2	[MMGE-002]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).