

| Room Name                             | 1 Bed Room - Special, Inboard Ensuite  | , Type 2   | Room Number 1BR-SP-A2  |
|---------------------------------------|--|--|--|
| Revision                              | 1  |  |  |
| Issue Date                            | 05.04.18   |  |  |
| BRIEFING                              |  |  |  |
| Briefed Area                          | 18.00 m <sup>2</sup>   |  |  |
| <b>Hours of Operation</b>             | 24 Hours   |  |  |
| Occupancy                             | 1 patient; 1-2 staff; 1-2 visitors   |  |  |
| Acoustics                             | Acoustic privacy is required   |  |  |
| Remarks                               |  |  |  |
| Description /<br>Special Requirements | It will typically be provided in maternity, paedia will accommodate (a) staff working at either sic predominately occur at the side of the bed clos panel reflects this assumption; (b) the movemenoist); (c) a ceiling mounted hoist. While the cepolicies; (d) room for a carer to stay overnight outlook is essential and the patients will need to | tric and palliative de of the bed, howest to the entry cent of equipment eiling hoist is shown to support models to have an extern used as an Isolat r ratings respond | wever it is assumed that nursing care will door. The arrangement of the medical services around all sides of the bed (e.g. a mobile wn, inclusion will be dependent on jurisdictional s such as 'care by parent'. Natural light and all outlook from either the chair or the bed, ion Room - Class S (Standard Pressure). Door to current AS 4586 and associated HB198 |
| SERVICES                              |  |  |  |
| General Requirements                  | BODY PROTECTED = Yes   | CARDIAC PRO  | OTECTED = No   |
| Air                                   | AIRCONDITIONING = Yes  | AIRCONDITIO  | NING: hepa filtered = No   |
|                                       | AIRCONDITIONING: positive pressure = No  |  | NING: negative pressure = No   |
| Lighting                              | LIC TING colour corrector = Yes LIGHTING: fluorescent/LED, downlights = No LIGHTING: fluorescent/LED, general = No   | LIGHT NG: dir  | nmage = No<br>wnlights, dimenable = No<br>orescent/LED, flush with ceiling, tamper   |
| Nurse Call                            | NURSE CALL SYSTEM = Yes  |  |  |

## Room Fabrics

| AusHFG code | Description  | Comment   |
|-------------|--|---|
| CLGE-001    | CEILING: plasterboard, bulkhead, paint                                   | joinery can optionally be used as bulkhead above cupboard   |
| CLFS-006    | CEILING: plasterboard, flush set, suspended, paint, washable             | tiles may also be acceptable<br>dependent upon acuity of<br>patient   |
| CLCN-008    | CORNICE: square set flush between wall and ceiling, paint                |   |
| DWGL-033    | DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint |   |
| DWPR-005    | DOOR PROTECTION: protection plate to 900 AFFL                            |   |
| DWPR-010    | DOOR PROTECTION: to door frame, PVC, prefinished                         | optional  |
| FLVY-007    | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant            | floor finish must be minimum<br>slip rating R10; Pendulum P3<br>or agreed equivalent to extend<br>under basin |
| FLSK-010    | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished                    |   |
| WLWA-004    | WALL FINISH: paint, acrylic, washable                                    |   |

AHHA
avitalisia kathi kirastuchar alliaco
eriziacia (alumini ya 1640 aki ya 1640 aki

Page: 1 Print Date: 03/04/2018





**Room Name** 

1 Bed Room - Special, Inboard Ensuite, Type 2

Room Number 1BR-SP-A2

| AusHFG code | Description                                      | Comment                           |
|-------------|--|-----------------------------------|
| WLWA-010    | WALL FINISH: splashback, vinyl                   | to basin                          |
| WLPR-001    | WALL PROTECTION: bed protection wall panel       |                                   |
| WLPR-011    | WALL PROTECTION: corner guards, to 900 AFFL min. |                                   |
| DWWH-005    | WINDOW   | natural light & outlook essential |

## Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description  | Group | Qty | Comment   |
|-------------|--|-------|-----|---|
| MMGE-002    | ADAPTER: suction   | 3     | 1   |   |
| HYBA-010    | BASIN: handwash, Type B                                    | 1     | 1   | refer to BHWS-B (similar)                             |
| MMBE-010    | BED: patient, electric with mattress                       | 3     | 1   |   |
| FQCW-016    | BIN: waste, general, 20L                                   | 3     | 1   | to basin  |
| DWWD-001    | BLIND: blackout  | 3     | 1   | provide additional anti glare<br>blind where required |
| FIHR-004    | BRACKET: for display screen, ceiling mounted               | 1     | 1   |   |
| FIHR-019    | BRACKET: for suction bottle                                | 2     | 1   |   |
| FQBS-055    | CHAIR: overnight fold out                                  | 3     | 1   |   |
| MMGE-019    | CHAIR: patient   | 3     | 1   |   |
| FIJO-130    | CUPBOARD: tall, single door, adj shelves and clothes rail  | 1     | 1   | wardrobe  |
| FQGE-010    | CURTAIN: rivacy s ree                                      | 3     | 1   |   |
| FIDI-001    | DISPENSER: alco of based hand rub                          | 2     | 1   |   |
| FIDI-014    | DISPENSER: disposable glove                                | 2     | 1   | to basin  |
| FIDI-025    | DISPENSER: paper/hand towel                                | 2     | 1   | to basin  |
| FIDI-030    | DISPENSER: soap  | 2     | 1   | to basin  |
| FIDI-031    | DISPENSER: soap antiseptic                                 | 2     | 1   | to basin  |
| ITBU-012    | DISPLAY SCREEN: patient entertainment system               | 1     | 1   |   |
| MGFP-002    | FLOWMETER: medical air                                     | 3     | 1   |   |
| MGFP-004    | FLOWMETER: oxygen  | 3     | 1   |   |
| MMBE-052    | LIFTER: patient, ceiling mounted, cassette motor for track | 1     | 1   | optional, for patient lifter track                    |
| MMBE-054    | LIFTER: patient, ceiling mounted, sling component          | 3     | 1   | optional, for patient lifter motor                    |
| MMBE-056    | LIFTER: patient, ceiling mounted, track, linear            | 1     | 1   | optional  |
| FQSN-051    | LOCKER: 2 drawers, open under, lockable, mobile            | 3     | 1   |   |
| MMGE-100    | SUCTION BOTTLE   | 3     | 1   |   |
| FQTA-013    | TABLE: overbed   | 3     | 1   |   |
| HYTP-037    | TAPWARE: mixer, elbow levers                               | 1     | 1   | to basin  |
| ITNE-049    | TELEPHONE: handset, desktop                                | 3     | 1   |   |
| FIRT-039    | TRACK: curtain, privacy, Z shaped, angled                  | 1     | 1   |   |
| FIBM-019    | WHITEBOARD: fixed, magnetic                                | 2     | 1   |   |

**Engineering Services** 



Page: 2 Print Date: 03/04/2018



**Room Name** 

1 Bed Room - Special, Inboard Ensuite, Type 2

Room Number 1BR-SP-A2

| AusHFG code | Description  | Group | Qty | Comment  |  |
|-------------|--|-------|-----|--|--|
| ITCL-004    | BUTTON: nurse call, emergency                          | 1     | 1   | + indicator button & light   |  |
| ITCL-006    | BUTTON: nurse call, patient to staff                   | 1     | 1   | on services panel, + indicator<br>button & light                                   |  |
| ITCL-008    | BUTTON: nurse call, staff assist                       | 1     | 1   | on services panel, + indicator<br>button & light                                   |  |
| ELGP-208    | GPO: double, wall mounted                              | 1     | 1   | bedhead low level, for electric bed  |  |
| ELGP-122    | GPO: emergency power, single, on services panel        | 1     | 4   | on services panel  |  |
| ELGP-101    | GPO: single, ceiling mounted                           | 1     | 1   | for ceiling mounted display screen   |  |
| ELGP-105    | GPO: single, on services panel                         | 1     | 4   | on services panel  |  |
| ELGP-109    | GPO: single, wall mounted                              | 1     | 1   |  |  |
| ELGP-110    | GPO: single, wall mounted, cleaner                     | 1     | 1   |  |  |
| ITCL-028    | HANDSET: nurse call, with patient to staff call button | 1     | 1   | on services panel, + light switch<br>on the handset                                |  |
| LIFX-017    | LIGHT: night light                                     | 1     | 1   |  |  |
| LIFX-011    | LIGHT: reading light                                   | 1     | 1   | up/down light  |  |
| ITIN-025    | OUTLET: data, double RJ45, on services panel           | 1     | 1   | on services panel, 1 outlet for telephone  |  |
| ITIN-070    | OUTLET: MATV   | 1     | 1   | for patient entertainment  |  |
|             |  |       |     | system. May be replace witl<br>data outlet, decision to be made<br>at project leve |  |
| MGAS-022    | OUTLET: r edical ir (Mar, on services p nel            | 1     | 1   | on services panel  |  |
| MGAS-042    | OUTLET: oxygen (O2), on services panel                 | 1     | 1   | on services panel  |  |
| MGAS-062    | OUTLET: suction, on services panel                     | 1     | 1   | on services panel  |  |
| ELPR-006    | RCD: residual current device                           | 1     | 2   | on services panel  |  |
| MMSP-026    | SERVICES PANEL: wall mounted                           | 1     | 1   |  |  |
| ELBO-015    | SWITCH: light, single                                  | 1     | 1   | on services panel  |  |
| ELBO-015    | SWITCH: light, single                                  | 1     | 3   |  |  |



Page: 3 Print Date: 03/04/2018

Generated from dRofus © 2017 dRofus Pty Ltd