Room Name	ADL Bed Room	Room Number: ADLBR

Last modified	01/03/2016
Briefed Area	15.00
Remarks	
Occupancy	*1 patient; 1-2 staff*
Hours of Operation	☑ *8am to 6pm, intermittent use*
Acoustics	*Acoustic privacy is required*
Description / Special Requirements	*Single Bed Room for Activities of Daily Living patient assessment and training; natural light and outlook is desirable; The room is to be lockable. The room furnishings will be domestic style to mimic home conditions.Acoustics: Acoustic privacy is required.Body Protected Electrical Area*

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.	Vinyl also acceptable
3000	Wall finish	Paint	Acrylic, washable		
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'
9001	Door - 1100mm	Solid Core	Paint	Single leaf	1100mm clear opening, lockable
7001	Windows				Desirable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH	or floor vinyl coved skirting

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13700	Mirror	1	1	optional
FF-2150	Chair - patient	3	1	
FF-22690	Table - bedside	3	1	heavy
FF-2655	Chair - visitor	3	1	
FF-4330	Cupboard - wardrobe	1	1	with hanging rail & shelves
FF-4900	Curtain track - window	1	1	to external window
FF-5410	Curtain - window, drapes	3	2	
FF-5900	Desk	3	1	
FF-690	Bed - domestic, single	3	1	

Fixtures, Equipment and associated Services

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	

Room Name | **ADL Bed Room** **Room Number: ADLBR**

AusHFG code	Description	Comments
S-6000	General fluorescent	
S-6050	Special: reading	Up/down light

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-9015	GPO: Cleaner	1	1	
S-9040	Body protected	1	1	
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	2	
S-6050	Special: reading	2	1	Up/down light
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light