



ADL Bathroom

Room Code	ADLB
Briefed Area	12.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 staff
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The ADL Bathroom provides a toilet, basin with vanity, shower and bath for the training and assessment of patients in Activities of Daily Living (ADL) tasks.

Electrical | PROTECTION: body protected ☒
PROTECTION: cardiac protected ☐

Lighting | LIGHTING: general ☒
LIGHTING: colour corrected ☐
LIGHTING: dimmable ☐
LIGHTING: indirect ☐

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset ☒

HVAC | AIRCONDITIONING: general ☐
AIRCONDITIONING: HEPA filtered ☐
AIRCONDITIONING: positive pressure ☐
AIRCONDITIONING: negative pressure ☐
VENTILATION: exhaust ☒
VENTILATION: natural ☐

Additional Considerations |

- The room is to provide domestic facilities with grab rails and other assistive devices to be included to reflect reasonable home modifications and equipment utilised by patients. The entrance of the room is to be flush with the adjoining corridor. The door is to be fitted with escape hardware for the door to open outwards if required.
- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements.
- The shower area may include a fixed raised hob to simulate a domestic scenario depending on service requirements.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-104.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid	[DWSC-021] with privacy latch and emergency release
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-006] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-113	FLOOR FINISH: vinyl, seamless, non-slip, wet area	[FLVY-009] significant change in colour from adjacent corridor to be avoided, to be suitable for bare feet, tiles are also acceptable
FLGE-151	SHOWER HOB: integrated with adjacent floor finish, vinyl	[FLGE-019] optional

CODE	DESCRIPTION	COMMENT
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-011.07	WALL FINISH: vinyl, full height	[WLWA-019] tiles also acceptable
CLTI-025.02	CEILING: drop-in tiles, moisture resistant, prefinished, 600 x 1200	[CLTI-014] water resistant flush set ceiling is also acceptable
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009] square set cornice acceptable if flush set ceiling is provided



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-007] dressing
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006] to basin
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-282	HOLDER: soap/shampoo, wall recessed	①	2	[FIDI-051]
FIDI-301	DISPENSER: toilet paper, wall mounted	①	1	[FIDI-036]
FIHR-026	HOOK: coat, wall mounted	①	4	[FIHR-026]
FIRT-051	TRACK: curtain, privacy	①	1	[FIRT-034] optional, dependent on infection control policy
FIRT-105	GRAB RAIL: 90 degree	①	1	[FIRT-048]
FIRT-125	GRAB RAIL: toilet, 90 degree	①	1	[FIRT-006] 1 is optional, dependent on service requirements
FIRT-136	GRAB RAIL: toilet, drop down	①	1	[FIRT-008] optional, dependent on service requirements and expected patient cohort
FIRT-151	GRAB RAIL: shower, straight, horizontal	①	1	[FIRT-003] may be combined with rail for hand held shower
FIRT-173	GRAB RAIL: bath, straight, vertical	①	1	[FIRT-044]
FQGE-102	CURTAIN: shower	③	2	[FQGE-011] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin
FQWS-331	BIN: sanitary waste	③	1	[FQCW-037] optional, dependent on waste management policy
HYBA-143	BASIN: type C, handwashing, with integral double shelf	①	1	[HYBA-002] shelf for patient belongings may be integral or separate
HYBA-201	BATH: domestic, built-in, straight	①	1	[HYBA-025] warm water
HYSH-056	SHOWER: hand-held, connection on wall, bracket on vertical wall mounted rail	①	1	[HYTP-021] to bath, vertical rail to have grabrail strength and fixings
HYSH-056	SHOWER: hand-held, connection on wall, bracket on vertical wall mounted rail	①	1	[HYTP-020] to shower, vertical rail to have grabrail strength and fixings
HYTP-051	TAPWARE: basin, mixer, fixture mounted	①	1	[HYTP-036] selection of basin and tapware to be coordinated to ensure compatibility
HYTP-251	TAPWARE: shower, mixer	①	2	[HYTP-039] diverter required for shower over bath
HYTP-331	TAPWARE: bath, spout, wall mounted	①	1	[HYTP-028]
HYWC-031	TOILET SUITE: patient	①	1	[HYWC-006] 100mm clearout access point optional
MMBE-038	TRANSFER AID: bench seat, patient self-assist transfer and positioning, freestanding	③	1	[FQBS-008] for over bath

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MMGE-024	CHAIR: shower	3	1	[MMGE-024] commode chair or combined shower/commode chair is also acceptable



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-202.01	GPO: double, wall mounted, power available indicator, horizontal	1	1	[ELGP-209]
ELSW-001	SWITCH: light	1	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	1	2	[HYDR-004]
ITCL-121	BUTTON: nurse call, patient to staff call, with cancel, wall mounted	1	3	[ITCL-006] optional; + indicator button & light
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	1	1	[ITCL-008] + indicator button & light
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] + indicator button & light

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).