



ADL Dining

Room Code	ADLD
Briefed Area	12.00 m ²
Ceiling Height	2.7 m
Occupancy	up to 4 patients; 1-2 staff
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The ADL Dining provides a flexible space for the training and assessment of patients in Activities of Daily Living (ADL) tasks. Typically collocated with the ADL Kitchen, the Dining room supports small group discussions and demonstrations between both rooms and provides a space for debriefing after training and assessment of ADL tasks in the Kitchen.

Electrical	PROTECTION: body protected	<input checked="" type="checkbox"/>	HVAC	AIRCONDITIONING: general	<input checked="" type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
Lighting	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>	
	LIGHTING: dimmable	<input type="checkbox"/>	VENTILATION: exhaust	<input type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input type="checkbox"/>	
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	<input checked="" type="checkbox"/>			

Additional Considerations |

- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. If multiple ADL rooms are combined into an ADL suite nurse call buttons can be rationalised into a central location.
- External outlook and access to natural light is desirable.

Doors and Windows

CODE	DESCRIPTION	COMMENT
WIFX-057.01	WINDOW: fixed, internal, double glazed, sill at 900H	[DWWH-005] desirable
AHWCV-001	WINDOW COVERING: blind, roller, single	[DWWC-004]

Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.01	WALL FINISH: vinyl, to 900 AFFL	[WLWA-022]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]
WLPR-006	WALL PROTECTION: corner guards	[WLPR-006]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQBS-151	CHAIR: dining areas	3	3	[FQBS-015]
FQGE-002	ARTWORK: wall mounted	3	1	[FQGE-002]
FQTA-226.05	TABLE: square, 750H nom, 1000L, adjustable height	3	1	[FQTA-085] height adjustable between 750-850H



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201.01	GPO: double, wall mounted, horizontal	1	2	[ELGP-208]
ELPR-071	RCD: residual current device, wall mounted	1	1	[ELPR-006]
ELSW-001	SWITCH: light	1	1	[ELBO-015]
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	1	1	[ITCL-008] + indicator button & light, may be rationalised to central location if collocated with other ADL Rooms
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] + indicator button & light, may be rationalised to central location if collocated with other ADL Rooms
ITSE-061	BUTTON: security, duress, fixed, wall mounted	1	1	[ITSE-006]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).