



ADL Laundry

Room Code	ADLL
Briefed Area	8.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1 staff
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The ADL Laundry provides domestic facilities for the training and assessment of patients in Activities of Daily Living (ADL) tasks. The room will include a domestic washing machine and dryer which, if front loading models are selected, may be placed on plinths to raise machines to an accessible height to support common ADL training and assessment tasks as per service requirements. A laundry tub and storage for ironing equipment are also provided.

Electrical | PROTECTION: body protected ☒
PROTECTION: cardiac protected ☐

Lighting | LIGHTING: general ☒
LIGHTING: colour corrected ☐
LIGHTING: dimmable ☐
LIGHTING: indirect ☐

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset ☐

HVAC | AIRCONDITIONING: general ☒
AIRCONDITIONING: HEPA filtered ☐
AIRCONDITIONING: positive pressure ☐
AIRCONDITIONING: negative pressure ☐
VENTILATION: exhaust ☒
VENTILATION: natural ☐

Additional Considerations |

- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. If multiple ADL rooms are combined into an ADL suite nurse call buttons can be rationalised into a central location.
- The space may be provided as an open bay that is collocated with other ADL rooms. If open, the impact of noise on adjacent areas must be considered.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-006] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-006] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-113	FLOOR FINISH: vinyl, seamless, non-slip, wet area	[FLVY-009]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]

CODE	DESCRIPTION	COMMENT
WLFI-101	SPLASHBACK: vinyl	[WLWA-007]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002] flush set ceiling is also acceptable
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009] square set cornice acceptable if flush set ceiling is provided



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	1	[FIJO-059] with inset laundry tub
JOCU-001	CUPBOARD: tall, single door	①	1	[FIJO-222]
JOCU-101	CUPBOARD: wall mounted, single door	①	1	[FIJO-156]
JOCU-221	CUPBOARD: under bench, double door	①	2	[FIJO-135]
JOGE-001	BULKHEAD: joinery	①	2	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	1	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to sink
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to sink
FQCL-101	WASHING MACHINE: laundry, domestic, front loading	③	1	[FQCW-063]
FQCL-111	DRYER: laundry, domestic	③	1	[FQGE-015]
FQCL-121	PLINTH: washing machine, domestic	③	2	[MMAH-039]
FQCL-152	APPLIANCE: iron, laundry, electric, domestic	③	1	[FQGE-028]
FQCL-186	TROLLEY: laundry basket	③	1	[FQSM-030] optional
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
HYBA-411	SINK: laundry, single bowl	①	1	[HYBA-064] with overflow drain, warm water
HYTP-152	TAPWARE: sink, mixer, fixture mounted, accessible	①	1	[HYTP-040]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	①	1	[ELGP-109] to washing machine and dryer
ELGP-201	GPO: double, wall mounted	①	1	[ELGP-208] 30mA RCD protection
ELPR-071	RCD: residual current device, wall mounted	①	1	[ELPR-006] type 1 10mA in accordance with AS/NZS 3003
ELSW-001	SWITCH: light	①	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	①	1	[HYDR-004]
HYTP-431	OUTLET: water, cold	①	1	[HYTP-008] to washing machine
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	①	1	[ITCL-008] + indicator button & light, may be rationalised to central location if collocated with other ADL Rooms

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] + indicator button & light, may be rationalised to central location if collocated with other ADL Rooms

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).