

Room Name | Ambulance Triage

Room Number: AMBTR

Last modified | 01/03/2016

Briefed Area | 12.00

Remarks

Occupancy

Up to 3

Hours of Operation

☒ 24 Hours

Acoustics

Description or Special Requirements

The Ambulance Triage is an area for receipt and assessment of patients arriving in the Unit by ambulance. The Ambulance Triage will be adjacent to the Ambulance entry which should include an Airlock.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin, tiles also acceptable
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL	Equal to Acrovyn, as required
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1110	Bench - laminate, writing	1	1	ambulance write-up
FF-1465	Bracket - suction bottle	2	2	optional
FF-150	Air flowmeter	3	1	optional
FF-16250	Oxygen flowmeter	3	2	optional
FF-19800	Shelf - laminate	1	1	to head of trolleys
FF-21950	Suction adapter	3	2	
FF-22000	Suction bottle	3	2	optional
FF-3350	Clock - battery operated	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-17001	Gurney		2	
FF-5824	Waste bin - general	3	1	

Room Name | Ambulance Triage

Room Number: AMBTR

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-54520	Telephone - handset, handsfree (WM)	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	2	monitor
S-9040	Body protected	1	1	
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	2	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	2	