

| Room Name | Anaesthetic Induction Room | Room Number: ANIN |
|------------------------------------|---|-------------------|
| Last modified | 01/03/2016 | |
| Briefed Area | 15.00 | |
| Remarks | | |
| Occupancy | 1 patient; up to 3 staff | |
| Hours of Operation | <input checked="" type="checkbox"/> Available 24 Hours | |
| Acoustics | Acoustic privacy is required | |
| Description / Special Requirements | <p>The Anaesthetic Room is for holding patients on mobile beds or trolleys prior to operative procedures at times when the Operating Room is not available. Local, regional or general anaesthesia may be administered in this area. Depending on special circumstances an Anaesthetic Induction Room of 18 m2 is also acceptable. Acoustics: Acoustic privacy is required Body Protected electrical area</p> | |

Room Fabrics

| AusHFG code | Description | Material | Finish | Specification | Comments |
|-------------|------------------------|-------------------|-------------------------|------------------------------------|--|
| 1000 | Floor finish | Vinyl | Standard slip resistant | Seamless, coved | |
| 3000 | Wall finish | Paint | Acrylic, washable | | |
| 3060 | Wall finish | Vinyl | Prefinished | Splashback | to basin, tiles also acceptable |
| 4020 | Wall protection | Composite | Prefinished PVC | Crash rail at 900 AFFL | Equal to 'Acrovyn' |
| 5010 | Ceiling - Plasterboard | Plasterboard | Paint, washable | Flush set, suspended | |
| 8010 | Door protection | Composite | Prefinished PVC | Protection plate to 900 AFFL | Equal to 'Acrovyn' |
| 8040 | Door protection | Composite | Prefinished PVC | To door frame | Equal to 'Acrovyn' |
| 9128 | Door - 1200mm | Solid Core/ Glass | Paint | 1 1/2 leaf, observation panel | 1500mm clear opening, sliding covers to obs panels |
| 6015 | Cornice | Plasterboard | Paint | Flush coved between wall & ceiling | |
| 2000 | Skirting | Vinyl | Prefinished | Floor vinyl coved, 150 mmH | |

Fittings and Furniture

| AusHFG code | Description | Group | Qty | Comments |
|-------------|-------------------------------------|-------|-----|-------------------------|
| FF-1050 | Bench - laminate | 1 | 1 | open under part |
| FF-12300 | Linen carrier - dirty, single | 3 | 1 | |
| FF-12900 | Wire panel - for storage-bins | 1 | 3 | 457mmx457mm, over bench |
| FF-1465 | Bracket - suction bottle | 2 | 2 | on equipment rail |
| FF-150 | Air flowmeter | 3 | 1 | |
| FF-15100 | Bracket - monitor | 3 | 1 | optional |
| FF-1567 | Cable/hose support arm - wall mount | 3 | 1 | optional |
| FF-16250 | Oxygen flowmeter | 3 | 2 | |
| FF-19700 | Sharps bin | 3 | 1 | on bench |
| FF-21755 | Storage bins | 3 | 10 | on louvred panels |
| FF-21950 | Suction adapter | 3 | 2 | |

Room Name | Anaesthetic Induction Room

Room Number: ANIN

| AusHFG code | Description | Group | Qty | Comments |
|-------------|------------------------------------|-------|-----|----------------------|
| FF-22000 | Suction bottle | 3 | 2 | |
| FF-23950 | Trolley | 3 | 1 | |
| FF-4380 | Cupboard - wall mount, glass front | 1 | 1 | over bench, lockable |
| FF-4410 | Cupboard - under bench | 1 | 2 | |
| FF-4430 | Cupboard - drawer unit | 1 | 1 | under bench |
| FF-6152 | Dispenser - disposable glove | 2 | 1 | |
| FF-6154 | Dispenser - paper/ hand towel | 2 | 1 | to basin |
| FF-6156 | Dispenser - soap | 2 | 1 | to basin |
| FF-6158 | Dispenser - soap antiseptic | 2 | 1 | to basin |
| FF-6163 | Dispenser - mask | 3 | 1 | to entry |
| FF-7300 | Rail - equipment | 1 | 1 | under services panel |
| FF-5824 | Waste bin - general | 3 | 1 | |
| FF-5975 | Waste bin - clinical | 3 | 1 | |

Fixtures, Equipment and associated Services

| AusHFG code | Description | Grp | Qty | Ele | Data | CdW | HtW | WmW | Tap | Dns | Gas | Comments |
|-------------|---------------------------------------|-----|-----|-------------------------------------|-------------------------------------|-------------------------------------|--------------------------|-------------------------------------|-------------------------------------|-------------------------------------|--------------------------|-----------------------|
| FE-3100 | Basin - scrub, Type A | 1 | 1 | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | refer to BHWS-A (sim) |
| FE-36055 | Monitor - cardiac with vital signs | 3 | 1 | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | optional |
| FE-43800 | Refrigerator - under-bench, 120 Litre | 3 | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | under bench, optional |
| FE-54510 | Telephone - handset, standard | 3 | 1 | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | to bench |
| FE-9750 | Clock - slave, analogue | 1 | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| FE-5857 | Light - procedures small, ceiling | 1 | 1 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |

Service Requirements

| AusHFG code | Description | Comments |
|-------------|-------------------------------|-----------------------------|
| S-9040 | Body protected | |
| S-5005 | Air conditioning: special | positive pressure, filtered |
| S-6001 | General: colour corrected | |
| S-6055 | Special: task light, built in | under O/H cupboards |

Services

Room Name | Anaesthetic Induction Room

Room Number: ANIN

| AusHFG code | Description | Group | Qty | Comments |
|-------------|----------------------------------|-------|-----|-------------------------------------|
| S-9000 | GPO: Single | 1 | 3 | Bedhead low level, for electric bed |
| S-9000 | GPO: Single | 1 | 4 | Bedhead low level, for electric bed |
| S-9010 | GPO: Emergency power, single (V) | 1 | 2 | monitor |
| S-9010 | GPO: Emergency power, single (V) | 1 | 1 | monitor |
| S-9010 | GPO: Emergency power, single (V) | 1 | 4 | monitor |
| S-9040 | Body protected | 1 | 1 | |
| S-9060 | GPO: Special: for equipment | 1 | 2 | TV, ceiling |
| S-1006 | Voice / Data outlet: double | 1 | 2 | 1 outlet for telephone |
| S-5005 | Air conditioning: special | 1 | 1 | positive pressure, filtered |
| S-6001 | General: colour corrected | 1 | 1 | |
| S-6200 | Light switches | 1 | 2 | |
| S-6055 | Special: task light, built in | 1 | 2 | under O/H cupboards |
| S-8010 | Staff/ Nurse assist call | 1 | 1 | + indicator button & light |
| S-8080 | Emergency call | 1 | 1 | + indicator button & light |
| S-8090 | Orderly/ Porter call | 1 | 1 | optional |
| S-1951 | Staff assist call | 1 | 1 | + indicator button & light |
| S-2072 | Scavenge Outlet | 1 | 1 | and controls, on wall, optional |
| S-7000 | Oxygen (O2) | 1 | 2 | |
| S-7010 | Nitrous Oxide (N2O) | 1 | 1 | services panel |
| S-7020 | Medical Air (MA) | 1 | 1 | |
| S-7040 | Suction | 1 | 2 | |
| S-7070 | Scavenge | 1 | 1 | services panel |
| S-11000 | Wall panel | 2 | 1 | patient services panels |