

**Room Name** | **Audiology Testing Room**

**Room Number: AUDIO**

**Last modified** | 01/03/2016

**Briefed Area** | 14.00

**Remarks**

**Occupancy**

Up to 3

**Hours of Operation**

☒ 8am to 6pm, daily

**Acoustics**

Acoustic privacy is required

**Description or Special Requirements**

Room with an internal sound proof booth to specifications, for audiology testing. Audiometric booth should be ventilated or connected to air-conditioning, power and data. Level access to the Audiometric Booth is recommended. Acoustics: Acoustic privacy requiredBody Protected electrical area

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.	
3000	Wall finish	Paint	Acrylic, washable		
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1600	Chair - child	3	1	as required
FF-1650	Chair - client	3	3	
FF-17250	Pedestal drawer unit - mobile, 660mmH	3	1	under desk
FF-2100	Chair - ergonomic, office	3	1	
FF-24400	Whiteboard	2	1	
FF-3400	Coathook	1	2	
FF-5900	Desk	3	1	
FF-22620	Table - adjustable height		1	
FF-5824	Waste bin - general	3	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-1600	Audiometric booth	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to specification
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	on desk

**Room Name** | Audiology Testing Room

**Room Number:** AUDIO

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6110	Downlights: dimmable	optional

## Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	5	
S-9015	GPO: Cleaner	1	1	
S-9040	Body protected	1	1	
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	3	
S-6110	Downlights: dimmable	1	1	optional
S-10005	Duress alarm	1	1	