



## Bathroom

Room Code	BATH
Briefed Area	15.00 m <sup>2</sup>
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 staff assisting
Hours of Operation	24 hours

**Description** | The Bathroom provides facilities for assisted bathing, dressing and grooming of patients.

<b>Electrical</b>	PROTECTION: body protected	<input checked="" type="checkbox"/>	<b>HVAC</b>	AIRCONDITIONING: general	<input type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>	
	LIGHTING: dimmable	<input type="checkbox"/>	VENTILATION: exhaust	<input checked="" type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input checked="" type="checkbox"/>	
<b>Nurse Call and Duress</b>	NURSE CALL SYSTEM: buttons / handset	<input checked="" type="checkbox"/>			

### Additional Considerations

- The layout is to allow for maneuvering of a patient on a lifting device, commode chair, wheelchair or shower trolley.
- A height adjustable bath may be provided instead of a shower trolley depending on service requirements.
- The location of the toilet should provide sufficient space on each side to allow for staff to provide assistance from either/both sides.
- Grab rails are to be securely fixed to the wall with the structural support required to meet weight ratings/SWL that must be confirmed at project level (generally accommodating patients up to 150kg for standard patient spaces). Provision of structural support and FF&E that is suitable for supporting bariatric patients (typically up to 250kgs) may be considered and confirmed at a project level.
- Signage with tactile Braille nominating 'Bathroom' required to room.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-104.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid	[DWSC-021] privacy latch
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-114	FLOOR FINISH: vinyl, seamless, non-slip, wet area, barefoot	[FLVY-009] tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided

CODE	DESCRIPTION	COMMENT
WLFI-011.07	WALL FINISH: vinyl, full height	[WLWA-019] tiles are also acceptable
CLFS-013	CEILING: flush set, suspended, moisture resistant	[CLFS-009]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-009]
CLCN-031	CORNICE: square set	[CLCN-008]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006] over basin
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-281	HOLDER: soap/shampoo, wall mounted	①	1	[FIDI-049] soap dispenser is also acceptable, to shower
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026]
FIRT-061	TRACK: curtain, shower	①	2	[FIRT-034] 1 to entry door, 1 to shower; optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FIRT-137	GRAB RAIL: toilet, drop down, with holder for toilet roll	①	1	[FIRT-008]
<i>FIDI-308</i>	<i>DISPENSER: toilet paper, to drop-down grab rail</i>	①	1	<i>Sub item to FIRT-137</i>
FIRT-138	GRAB RAIL: toilet, drop down, with bracket for nurse call button	①	1	[FIRT-008]
FIRT-153	GRAB RAIL: shower, straight, vertical	①	1	with bracket for hand held shower mounted on vertical rail
FIRT-166	GRAB RAIL: shower, T-shaped, vertical and horizontal	①	1	[FIRT-045] with bracket for hand held accessible shower mounted on vertical rail
FIRT-191	BACK REST: toilet, accessible	①	1	[FIGE-011]
FIRT-206	RAIL: towel, wall mounted	①	1	[FIRT-016] with grab rail strength/fixings
FQGE-102	CURTAIN: shower	③	2	[FQGE-011] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
FQWS-331	BIN: sanitary waste	③	1	[FQCW-037]
HYBA-148	BASIN: type C, handwashing, accessible, with integral double shelf	①	1	[HYBA-005] with detachable shroud to pipework; location of thermostatic mixing valve to be determined based on ability to share with nearby basins
HYSH-056	SHOWER: hand-held, connection on wall, bracket on vertical wall mounted rail	①	1	[HYTP-020]
HYSH-057	SHOWER: hand-held, connection on wall, bracket on vertical wall mounted rail, accessible	①	1	[HYTP-045]
HYTP-052	TAPWARE: basin, mixer, fixture mounted, accessible	①	1	[HYTP-035] selection of basin and tapware to be coordinated to ensure compatibility
HYTP-251	TAPWARE: shower, mixer	①	2	[HYTP-039]
HYWC-033	TOILET SUITE: patient, accessible	①	1	[HYWC-001]
MMBE-161	TROLLEY: patient, shower, hydraulic	③	1	[FQSM-033] height adjustable bath is also acceptable
MMGE-024	CHAIR: shower	③	1	[MMGE-024] commode chair is also acceptable



CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	①	1	[ELGP-208] IPX4 rating required
ELSW-001	SWITCH: light	①	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	①	2	[HYDR-004] special floor drain required if height adjustable bath provided
HYDR-201	DIRECT CONNECTION: wastewater, general	①	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	①	2	1 to basin tapware, 1 to shower
HYTP-453	DIRECT CONNECTION: water, warm	①	2	1 to basin tapware, 1 to shower
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	①	1	outside door
ITCL-122	BUTTON: nurse call, patient to staff call, with cancel, wall mounted, wet area	①	1	[ITCL-006] IPX4 rating required; to shower
ITCL-130	BUTTON: nurse call, patient to staff call, with cancel, to drop-down grab rail, wet area	①	1	[ITCL-006] IPX4 rating required
ITCL-192	BUTTON: nurse call, emergency, with cancel, wall mounted, wet area	①	1	[ITCL-004] IPX4 rating required

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).