



Bay - Handwashing, Type A

Room Code	BHWS-A
Briefed Area	1.00 m ²
Ceiling Height	2.7 m
Occupancy	1 person intermittently
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Bay - Handwashing, Type A provides handwashing facilities for staff use in areas requiring clinical handwashing prior to undertaking selected procedures and where handwashing up to the elbow may be necessary.

Electrical	PROTECTION: body protected <input type="checkbox"/>	HVAC	AIRCONDITIONING: general <input checked="" type="checkbox"/>
	PROTECTION: cardiac protected <input type="checkbox"/>		AIRCONDITIONING: HEPA filtered <input type="checkbox"/>
Lighting	LIGHTING: general <input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	LIGHTING: colour corrected <input type="checkbox"/>	VENTILATION: exhaust <input type="checkbox"/>	VENTILATION: natural <input type="checkbox"/>
	LIGHTING: dimmable <input type="checkbox"/>		
	LIGHTING: indirect <input type="checkbox"/>		
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset <input type="checkbox"/>		

- Additional Considerations**
- The basin is to be a large, wall-mounted, 'scrub' type, with hands-free taps that may be wall-mounted elbow operated, foot/knee operated or operated with electronic sensor taps.
 - Warm and cold water are to be delivered by a common spout.



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-111	FLOOR FINISH: vinyl, seamless, non-slip	[FLVY-003] floor finish of adjacent area may continue under basin but must have a minimum slip rating R10/pendulum P3 or agreed equivalent or an inset section of non-slip vinyl is required; significant change in colour to be avoided.
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-101	SPLASHBACK: vinyl	[WLWA-007]
CLFS-011	CEILING: flush set, suspended	[CLFS-006] drop-in ceiling tiles are also acceptable; to be coordinated with adjacent area
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008] coordinated with adjacent area
WLPR-006	WALL PROTECTION: corner guards	[WLPR-006] if bay is recessed



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-231	DISPENSER: paper towel, wall mounted	2	1	[FIDI-025]
FIDI-256	DISPENSER: soap, wall mounted	2	1	[FIDI-030]
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	2	1	[FIDI-031]
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016]
HYBA-101	BASIN: type A, handwashing	1	1	[HYBA-009]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	1	1	[HYTP-037]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
HYDR-201	DIRECT CONNECTION: wastewater, general	1	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	1	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	1	1	to basin tapware

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).