



Bay - Handwashing, Type B

Room Code	BHWS-B
Briefed Area	1.00 m ²
Ceiling Height	2.7 m
Occupancy	1 person intermittently
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Bay - Handwashing, Type B provides handwashing facilities for staff use before and after every patient contact and visitor use as required.

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations |

- The basin is to be a medium, wall-mounted type, with hands-free taps that may be either wall-mounted or basin-mounted elbow operated taps.
- Warm and cold water are to be delivered by a common spout.



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-111	FLOOR FINISH: vinyl, seamless, non-slip	[FLVY-003] floor finish of adjacent area may continue under basin but must have a minimum slip rating R10/pendulum P3 or agreed equivalent or an inset section of non-slip vinyl is required; significant change in colour to be avoided.
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-101	SPLASHBACK: vinyl	[WLWA-007]
CLFS-011	CEILING: flush set, suspended	[CLFS-006] drop-in ceiling tiles are also acceptable; to be coordinated with adjacent area
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008] coordinated with adjacent area
WLPR-006	WALL PROTECTION: corner guards	[WLPR-006] if bay is recessed



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030]
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] optional, dependent on service requirements
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
HYBA-121	BASIN: type B, handwashing	①	1	[HYBA-010]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).