

# **Standard Components - Room Data Sheet**

with a lever, or a flickmixer tap for general handwashing.

Room Name Bay - Handwashing, Type C Room Number: BHWS-C

Last modified 01/03/2016

Briefed Area Remarks
Occupancy 1
Hours of Operation Acoustics
Description / Special Requirements

Handwashing facilities for staff, patients and public amenity. Type C refers to a Small to Medium hand basin

## **Room Fabrics**

AusHFG code	Description	Material	Finish	Specification	Comments
2675	Floor finish	Vinyl, non slip		Seamless coved	Significant change in colour to be avoided.
3000	Wall finish	Paint	Acrylic, washable		
2708	Wall finish			Splashback to basin	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
2670	Wall protection			Corner guards to 900 AFFL minimum	Align heights of corner guards with other corridor elements
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	Acoustic tiles acceptable.
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## **Fittings and Furniture**

AusHFG code	Description	Group	Qty	Comments
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	
FF-6156	Dispenser - soap	2	1	
FF-5824	Waste bin - general	3	1	

# Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Comments
FE-2850	Basin - handwash, Type C (with vanity)	1	1			V		V	<b>V</b>	V		Basin mounted lever or single lever mixer tap.

## **Service Requirements**

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

#### **Services**

AusHFG code	Description	Group	Qty	Comments
S-5000	Airconditioning	1	1	







# **Standard Components - Room Data Sheet**

Room Name Bay - Handwashing, Type C Room Number: BHWS-C

AusHFG code	Description	Group	Qty	Comments
S-6000	General fluorescent	1	1	



