

Room Name
Bay - Pathology
Room Number: BPATH
Last modified

01/03/2016

Briefed Area

1.00

Remarks
Occupancy

1 - 2 staff

Hours of Operation
☒ 24 Hours

Acoustics
Description / Special Requirements

A space for the preparing and testing a range of specimens. This space has been based on four (4) benchtop POCT devices. This level of provision may be more common in critical care areas. The space is dependent on the number of devices used in each clinical situation. In a multi-device bay, 300mm gap between each device is recommended. Design to consider height clearances if above bench joinery is installed. This space to be colocated with a pneumatic tube bay and in an area that is supervised by staff. Assumes that staff will access a hand hygiene bay nearby. The workspace will suit a staff member who is standing. Design consideration as to the weight of some POCT devices.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
2670	Wall protection			Corner guards to 900 AFFL minimum	Align heights of corner guards with other corridor elements
5007	Ceiling - Plasterboard	Plasterboard	Paint	Bulkhead	Between above bench joinery and ceiling.
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	Acoustic tiles acceptable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	With optional inset sink. Length to suit layout, refer RLS or project specific requirements.
FF-12900	Wire panel - for storage-bins	1	1	Over bench. Number to suit layout.
FF-1470	Bracket - sharps	2	1	Optional.
FF-19700	Sharps bin	3	1	Optional.
FF-21755	Storage bins	3	2	Number to suit.
FF-4410	Cupboard - under bench	1	2	With adjustable shelf. Number to suit layout, refer RLS or project specific requirements.
FF-4470	Cupboard - wall mounted, lockable (s)	1	4	Over bench. Number to suit layout, refer RLS or project specific requirements.
FF-24124	Waste bin - clinical, 20 litres		1	
FF-5830	Dispenser - antiseptic hand rub	2	1	May not be required if Hand Hygiene Bay colocated.

Room Name | Bay - Pathology

Room Number: BPATH

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-43800	Refrigerator - under-bench, 120 Litre	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Local temperature monitoring. Optional, depends on frequency of collection.
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Bench or wall mounted, optional.
FE-6459	Point-of-Care device	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Number to be project specific.
FE-41150	Printer - labels	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6055	Special: task light, built in	under O/H cupboards

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	4	
S-9011	GPO: Emergency power, double (H)	1	1	for refrigerator
S-1006	Voice / Data outlet: double	1	4	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6055	Special: task light, built in	1	2	under O/H cupboards