



Bay - Water Fountain

Room Code	BWTR
Briefed Area	1.00 m ²
Ceiling Height	2.7 m
Occupancy	1 person intermittently
Hours of Operation	Available 24 hours (dependent on unit operating hours)

Description | The Bay - Water Fountain is typically associated with a main entry lobby or waiting area, and provides area, fittings and services connections for a drinking water fountain.

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations |

- The water fountain may be in a recessed bay or in an open area and should be located to ensure adjacent circulation paths are not impeded by intermittent use.
- A water dispenser with a spout to fill disposable cups or refill drink bottles is recommended.
- Hand hygiene facilities, such as alcohol-based hand rub, should be provided nearby in line with local infection prevention and control (IPC) policies.



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-111	FLOOR FINISH: vinyl, seamless, non-slip	[FLVY-003] floor finish of adjacent area may continue under water fountain but must have a minimum slip rating R10/pendulum P3 or agreed equivalent or an inset section of non-slip vinyl is required; significant change in colour to be avoided.
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.03	WALL FINISH: vinyl, to 1200 AFFL	[WLWA-025]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002] to be coordinated with adjacent area
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009] to be coordinated with adjacent area



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-196	DISPENSER: disposable cup, wall mounted	②	1	[FQCA-014]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
HYGE-052	DRINKING FOUNTAIN: wall mounted, accessible	①	1	[HYGE-011]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-102	GPO: single, wall mounted, power available indicator	①	1	[ELGP-111] optional, for refrigerated units only

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).