



## Change Room - Patient (Male/ Female), 12m<sup>2</sup>

<b>Room Code</b>	CHPT-12
<b>Briefed Area</b>	12.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	up to 3 patients intermittently
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | The Change Room - Patient provides the area and amenities required for ambulant patients to change into appropriate clothes prior to physical therapy or hydrotherapy sessions, and to re-dress and perform personal ablutions afterwards.

**Electrical** | PROTECTION: body protected   
PROTECTION: cardiac protected

**Lighting** | LIGHTING: general   
LIGHTING: colour corrected   
LIGHTING: dimmable   
LIGHTING: indirect

**Nurse Call and Duress** | NURSE CALL SYSTEM: buttons / handset

**HVAC** | AIRCONDITIONING: general   
AIRCONDITIONING: HEPA filtered   
AIRCONDITIONING: positive pressure   
AIRCONDITIONING: negative pressure   
VENTILATION: exhaust   
VENTILATION: natural

### Additional Considerations

- Change Rooms are typically divided into gender specific areas on a proportional basis. and will include Change Cubicle, Toilet, handbasin and lockers for secure storage of personal property.
- Operational models for handling patient belongings are to be considered. The change room may include facilities for temporarily storing clothes, or close proximity to patient lockers or other secure property storage may be required where belongings are not to be kept with the patient.
- Grab rails are to be securely fixed to the wall with the structural support required to meet weight ratings/SWL that must be confirmed at project level (generally accommodating patients up to 150kg for standard patient spaces). Provision of structural support and FF&E that is suitable for supporting bariatric patients (typically up to 250kgs) may be considered and confirmed at a project level.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] privacy latch, with emergency release
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-006] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-006] to room side
AFDPR-056.01	DOOR FRAME PROTECTION: full wrap, to 900H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] minimum slip rating R10/ Pendulum P3 or agreed equivalent to extend under basin or an inset section of non-slip vinyl is required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLPT-062	PARTITION SYSTEM: cubicle, toilet, ambulant	[WLPT-005]
WLPT-051	PARTITION SYSTEM: cubicle, changing	[WLPT-001]
WLPT-054	PARTITION SYSTEM: integral seat, changing	[FIGE-003] chair is also acceptable; confirm weight capacity requirements
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLTI-021.02	CEILING: drop-in tiles, prefinished, 600 x 1200	[CLTI-008] flush set ceiling is also acceptable
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-002] square set cornice acceptable if flush set ceiling is provided



## Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOSH-401	SHELF: wall mounted, laminate	①	1	[FJO-191] over basin; provision of basin with integral shelf is also acceptable



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-301	DISPENSER: toilet paper, wall mounted	①	1	[FIDI-036]
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026]
FIRT-125	GRAB RAIL: toilet, 90 degree	①	2	[FIRT-006] Ambulant provision.
FQCL-211	LINEN CARRIER: dirty, single skip	③	1	[MMGE-048]
FQGE-121	CLOCK: analogue display, battery operated	③	1	[FQGE-005] optional
FQSN-322	LOCKER: floor standing, 2 door, on plinth	③	4	[FQSN-048] quantity and size of lockers to suit service requirements
FQSN-342	LOCKER: floor standing, 4 door, on plinth	③	2	[FQSN-050] quantity and size of lockers to suit service requirements
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
FQWS-331	BIN: sanitary waste	③	1	[FQCW-037] optional, to be provided to female change rooms
HYBA-141	BASIN: type C, handwashing	①	1	[HYBA-011] with detachable shroud to pipework; location of thermostatic mixing valve to be determined based on ability to share with nearby basins
HYTP-051	TAPWARE: basin, mixer, fixture mounted	①	1	[HYTP-036] selection of basin and tapware to be coordinated to ensure compatibility
HYWC-031	TOILET SUITE: patient	①	1	[HYWC-006]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MMTR-121	TROLLEY: gowns/scrubs, 1060W x 490D x 1830H nominal	3	1	[MMGE-122] optional



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	1	1	[ELGP-208] optional
ELSW-001	SWITCH: light	1	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	1	1	[HYDR-004]
HYDR-201	DIRECT CONNECTION: wastewater, general	1	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	1	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	1	1	to basin tapware
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	1	1	outside door
ITCL-121	BUTTON: nurse call, patient to staff call, with cancel, wall mounted	1	2	[ITCL-006] 1 to toilet cubicle, 1 to change cubicle
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	1	1	[ITCL-008]
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).