



Change - Staff, 10m2

Room Code	CHST-10
Briefed Area	10.00 m ²
Ceiling Height	2.7 m
Occupancy	up to 3 staff intermittently
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Change - Staff, 10m2 provides the space and fit-out for staff to change into appropriate work clothing or gowns, to store their street clothing and to perform personal ablutions. The room may be comprised of a combination of showers, toilets, basins and lockers, with numbers to suit service and staff requirements.

Electrical	PROTECTION: body protected	<input type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>
Lighting	LIGHTING: general	<input checked="" type="checkbox"/>
	LIGHTING: colour corrected	<input type="checkbox"/>
	LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: indirect	<input type="checkbox"/>
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>

HVAC	AIRCONDITIONING: general	<input checked="" type="checkbox"/>
	AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>
	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	VENTILATION: exhaust	<input checked="" type="checkbox"/>
	VENTILATION: natural	<input type="checkbox"/>

Additional Considerations

- Change rooms are typically allocated as separate male and female areas and sized on a proportional basis.
- Secure storage for personal property (e.g. lockers) may be provided within the change room or separately within the unit dependent on operational policies and service requirements.
- Accessible change facilities for staff to be provided nearby.
- A proportion (minimum 2%) of lockers may be required to be accessible with locking devices located between 900mm to 1100mm AFFL.
- Secure, staff-only access to change rooms is required.
- Visual privacy from the entry door to the changing areas and cubicles is to be considered during planning.
- If provided for staff to change for sterile procedures, access to clean linen will be required



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-002.01	DOOR: hinged, 1 leaf, 850 clear opening, solid	[DWSC-001] with closer as required for privacy
<i>AFDPR-001.01</i>	<i>DOOR PROTECTION: kickplate, to 300H</i>	<i>[DWPR-001] to room side</i>
<i>AFDPR-006.01</i>	<i>DOOR PROTECTION: plate, to 900H</i>	<i>[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection</i>
<i>ITSE-261</i>	<i>READER: security, access control, proximity card, wall mounted</i>	<i>[ITSE-038]</i>



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-114	FLOOR FINISH: vinyl, seamless, non-slip, wet area, barefoot	[FLVY-009] tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.06	WALL FINISH: vinyl, to 2100 AFFL	[WLWA-023] to shower; tiles are also acceptable
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
WLPT-071	PARTITION SYSTEM: cubicle, shower	[WLPT-004]
WLPT-061	PARTITION SYSTEM: cubicle, toilet	[WLPT-005] lift off hinges to inward opening sanitary compartment doors
CLFS-013	CEILING: flush set, suspended, moisture resistant	[CLFS-009] moisture resistant drop-in ceiling tiles are also acceptable
CLFI-001	CEILING FINISH: paint	[CLFS-009]
CLCN-031	CORNICE: square set	[CLCN-008] wall trim fixing acceptable if drop-in ceiling tiles are provided



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212] optional, over lockers; plasterboard bulkhead is also acceptable



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006] to basin
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-256	DISPENSER: soap, wall mounted	②	2	[FIDI-030] 1 to basin, 1 to shower
FIDI-281	HOLDER: soap/shampoo, wall mounted	①	1	[FIDI-049] optional, to shower
FIDI-301	DISPENSER: toilet paper, wall mounted	①	1	[FIDI-036]
FIGE-021	BENCH SEAT: fixed, indoor, wall mounted	①	2	[FIGE-003] to changing area
FIGE-023	BENCH SEAT: fixed, indoor, wet area, wall mounted	①	1	[FIGE-003] to shower cubicle
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026] 1 to toilet cubicle, 1 to shower cubicle
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026] optional, to changing area; quantity to be based on staffing and service requirements
FIRT-061	TRACK: curtain, shower	①	1	[FIRT-033] optional
FQCL-211	LINEN CARRIER: dirty, single skip	③	1	[MMGE-048]
FQGE-102	CURTAIN: shower	③	1	[FQGE-011] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FQSN-323	LOCKER: floor standing, 2 door, with shoe storage	③	2	[FQSN-054]
FQSN-343	LOCKER: floor standing, 4 door, with shoe storage	③	2	[FQSN-055]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQWS-331	BIN: sanitary waste	③	1	[FQCW-037] optional, to toilet in female change rooms
HYBA-143	BASIN: type C, handwashing, with integral double shelf	①	1	[HYBA-012]
HYSH-001	SHOWER: fixed rose, wall mounted	①	1	[HYTP-018]
HYTP-051	TAPWARE: basin, mixer, fixture mounted	①	1	[HYTP-036] selection of basin and tapware to be coordinated to ensure compatibility
HYTP-251	TAPWARE: shower, mixer	①	1	[HYTP-039]
HYWC-021	TOILET SUITE: standard	①	1	[HYWC-008] with clear out access point



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201.01	GPO: double, wall mounted, horizontal	①	1	[ELGP-208]
ELSW-001	SWITCH: light	①	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	①	1	[HYDR-004]
HYDR-081	DRAIN: clear out, round	①	1	[HYDR-009]
HYDR-201	DIRECT CONNECTION: wastewater, general	①	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	①	2	1 to basin tapware, 1 to shower
HYTP-453	DIRECT CONNECTION: water, warm	①	2	1 to basin tapware, 1 to shower

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).