

Standard Components - Room Data Sheet

Room Name | Clean-Up Room, 7m2 Room Number: CLUP-7

Last modified 01/03/2016

Briefed Area Remarks 7.00

Acoustics

Description or Special Requirements

The Clean-Up Room is used for holding of used trolleys and articles from an Operating or Procedure room. Items may be sorted, rinsed or disposed of and despatched to waste holding/ CSSU areas as appropriate.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL	
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL	As required; Equal to Acrovyn
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1010	Bench - stainless steel	1	1	with wet edge
FF-12300	Linen carrier - dirty, single	3	1	
FF-1470	Bracket - sharps	2	1	
FF-15400	Hook rack - mops	1	1	4 hooks
FF-19700	Sharps bin	3	1	
FF-19820	Shelf - SS, under	1	1	under SS bench
FF-20000	Shelving unit - adjustable	1	1	over bench
FF-23950	Trolley	3	1	
FF-24125	Waste bin - clinical	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	
FF-5824	Waste bin - general	3	1	

Fixtures, Equipment and associated Services







Standard Components - Room Data Sheet

Room Name | Clean-Up Room, 7m2 | Room Number: CLUP-7

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1			V		V	V	V		elbow action levers
FE-49111	Sink - 450x350x250D	1	1			V	V	V	V	V		hot water
FE-49200	Sink - cleaner	1	1			V	V		V	V		
FE-4045	Tapware - long elbow mixer		1									
FE-4045	Tapware - elbow mixer		1									

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-4033	Floor waste	1	1	
S-5000	Airconditioning	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	



