



Consult Room

Room Code	CONS
Briefed Area	12.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 visitors; 1-2 staff
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Consult Room will provide for private consultation and physical examination of patients with or without support persons present.

Electrical	PROTECTION: body protected <input checked="" type="checkbox"/>	HVAC	AIRCONDITIONING: general <input checked="" type="checkbox"/>
	PROTECTION: cardiac protected <input type="checkbox"/>		AIRCONDITIONING: HEPA filtered <input type="checkbox"/>
Lighting	LIGHTING: general <input type="checkbox"/>	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	LIGHTING: colour corrected <input checked="" type="checkbox"/>	VENTILATION: exhaust <input type="checkbox"/>	VENTILATION: natural <input type="checkbox"/>
	LIGHTING: dimmable <input type="checkbox"/>		
	LIGHTING: indirect <input type="checkbox"/>		
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset <input checked="" type="checkbox"/>		

Additional Considerations

- A second door may be required for staff safety and security; the location of the second door will be dependent on the availability an appropriate area to egress.
- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005] 1 1/2 leaf door is also acceptable as required
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area
DOHI-012.01	DOOR: hinged, 1 leaf, 850 clear opening, solid, standard vision panel	[DWGL-077] optional, second door for egress
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.03	WALL FINISH: vinyl, to 1200 AFFL	[WLWA-025] to patient/visitor chairs
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020] to exam couch
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	1	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	②	1	[FIBM-019] optional
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006]
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-223	DISPENSER: paper bed roll, exam couch mounted	③	1	[FIDI-003] may be provided as an attachment to exam couch
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026]
FIHR-101	BRACKET: suction bottle, wall mounted	②	1	[FIHR-019] optional, provide if suction required
FIHR-111	BRACKET: sharps bin, wall mounted	②	1	[FIHR-016]
FIRT-051	TRACK: curtain, privacy	①	1	[FIRT-032]
FQBS-101	CHAIR: visitor, clinical areas	③	3	[FQBS-058] consider weight capacity of chairs
FQBS-171	CHAIR: office, ergonomic	③	1	[FQBS-018]
FQDW-134.03	WORKSTATION: straight, adjustable height, 720H nom, 750D x 1500W	③	1	[FQDW-037]
FQGE-101	CURTAIN: privacy screen	③	1	[FQGE-010]
FQWS-003	BIN: sharps, clinical, medium	③	1	[FQCW-044]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016] to basin
HYBA-121	BASIN: type B, handwashing	1	1	[HYBA-010]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	1	1	[HYTP-037]
ITNE-071	TELEPHONE: handset, desktop	3	1	[ITNE-050]
ITNE-101	COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop	3	1	[ITNE-007] high resolution monitor for PACS viewing
ITNE-311	PRINTER: desktop	3	1	[ITNE-023] optional
LIFX-114	LIGHT: examination, single articulated arm, 1 light head, wall mounted	1	1	[LIFX-026] may be ceiling mounted
MMBE-171	COUCH: patient, examination, electric	3	1	[MMBE-023] hi/low operation
MMGE-191	CANNISTER: suction bottle	3	1	[MMGE-100] optional, provide if suction required
MMGE-231	DIAGNOSTIC SET: otoscope and ophthalmoscope, portable	3	1	[MMGE-030] may be wall mounted/mobile on stand



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	1	1	[ELGP-109] low level, for electric couch
ELGP-101	GPO: single, wall mounted	1	1	[ELGP-109] for exam light
ELGP-201	GPO: double, wall mounted	1	3	[ELGP-208] 2x below desk, 1x above desk
ELPR-071	RCD: residual current device, wall mounted	1	3	[ELPR-006]
ELSW-001	SWITCH: light	1	2	[ELBO-015] 1 to exam light
HYDR-201	DIRECT CONNECTION: wastewater, general	1	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	1	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	1	1	to basin tapware
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	1	1	outside door
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	1	1	[ITCL-008] + indicator button & light
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] + indicator button & light
ITCL-251	HANDSET: nurse call, patient to staff call	1	1	[ITCL-028]
ITIN-036	OUTLET: data, triple RJ45, wall mounted	1	1	[ITIN-036] to desk
ITSE-061	BUTTON: security, duress, fixed, wall mounted	1	1	[ITSE-006] in discreet location easily accessible by staff



Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	1	1	[MMSP-026]
ELGP-216	GPO: double, on services panel	1	1	[ELGP-205]
ELGP-246	GPO: double, emergency power, on services panel	1	1	[ELGP-222]
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	[ITIN-025]
MGAS-022	OUTLET: medical air, on services panel	1	1	[MGAS-022] optional

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MGAS-042	OUTLET: oxygen (O2), on services panel	①	1	[MGAS-042] optional
MGAS-062	OUTLET: suction, on services panel	①	1	[MGAS-062] optional
MGFP-021	FLOWMETER: medical air	③	1	[MGFP-002] optional, provide if medical air required
MGFP-041	FLOWMETER: oxygen	③	1	[MGFP-004] optional, provide if oxygen required
MGFP-061	ADAPTER: suction	③	1	[MMGE-002] optional, provide if suction required

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).