



## Dining - Patient

<b>Room Code</b>	DINR
<b>Briefed Area</b>	40.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	up to 16 patients seated; 3-4 staff intermittently
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | The Dining Room is an area provided for patients to eat their meals away from the bedroom environment in an inpatient setting. The Dining Room may be used for other patient recreational activities when not in use for meals. In this instance, additional transfer of noise to adjacent patient care areas to be considered.

**Electrical** | PROTECTION: body protected   
 PROTECTION: cardiac protected

**Lighting** | LIGHTING: general   
 LIGHTING: colour corrected   
 LIGHTING: dimmable   
 LIGHTING: indirect

**Nurse Call and Duress** | NURSE CALL SYSTEM: buttons / handset

**HVAC** | AIRCONDITIONING: general   
 AIRCONDITIONING: HEPA filtered   
 AIRCONDITIONING: positive pressure   
 AIRCONDITIONING: negative pressure   
 VENTILATION: exhaust   
 VENTILATION: natural

**Additional Considerations**

- Food services model, e.g. meal trolley (tray or re-thermalisation), servery, beverage bay, etc. will impact room design. A kitchen, servery or beverage bay may be collocated or combined with the Dining Room.
- Size of space will depend on number of beds and models of care; designed area based on 3m<sup>2</sup> per person.
- Access will be required for patients with limited mobility including wheelchairs, walking frames and other walking aids. Design must also consider the needs of patients with dementia and frail/elderly.
- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. Patient to nurse call button and handset is optional and may be provided in units where high patient observation is required.
- Duress provision will be dependent on service requirements.
- Furniture shown in this Standard Component is indicative and items selected will vary depending on patient cohort. Considerations regarding furniture include assessing the weight rating of all seating, including for bariatric capacity as required, providing a mix of chairs with and without arms to support patient mobility, and providing built-in furniture or securing furniture where there may be safety/security concerns.
- Lighting to be consistent across the space.
- Size, type and quantity of waste bins is dependent on environmental management policies and service requirements. Where a facility has additional waste streams, beyond the general waste and comingled recycling indicatively shown in this Standard Component, additional area may be required to accommodate the receptacles. Depending on frequency of waste removal, bin sizes may be larger in high use areas or as guided by local waste management policies. Joinery to conceal bins may be provided depending on infection prevention and control policies.
- Where possible a achieving a domestic appearance with furniture, fittings and finishes is recommended.
- The display of artwork and cultural assets will be guided by the facility. A rail display system may be considered to minimise risks and allow for flexibility in display. Ease of cleaning for infection prevention and control also needs to be considered when selecting artwork.
- Natural light and external outlook is essential.



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-144.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, wide vision panel	[DWGL-031] with hold open device to support trolley movement as required
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
WIFX-158.01	WINDOW: fixed, external, double glazed, sill at 1050H	[DWWH-005] natural light and external outlook is essential
AHWCV-001	WINDOW COVERING: blind, roller, single	[DWWD-004]
WIFX-158.01	WINDOW: fixed, external, double glazed, sill at 1050H	[DWWH-005] natural light and external outlook is essential
AHWCV-001	WINDOW COVERING: blind, roller, single	



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10/pendulum P3 or agreed equivalent to extend under basin; significant change in colour to be avoided
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, covered	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.03	WALL FINISH: vinyl, to 1200 AFFL	[WLWA-025] to meal trolley parking area
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



## Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	1	[FIJO-059]
JODW-031	DRAWER UNIT: under bench, 3 drawers, equal	①	1	[FIJO-104]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	2	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-331	BRACKET: display screen, single, fixed, wall mounted	②	1	[FIHR-006] optional
FQBS-151	CHAIR: dining areas	③	16	[FQBS-015] furniture is indicative and selection will be dependent on patient/visitor cohort and service requirements

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQCA-082	TROLLEY: food delivery, hot/cold	3	1	[FQCA-082] as required to suit food service model
FQGE-002	ARTWORK: wall mounted	3	1	[FQGE-002]
FQTA-226.01	TABLE: square, 750H, 1000L	3	4	[FQTA-059] furniture is indicative and selection will be dependent on patient/visitor cohort and service requirements
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016] to basin
FQWS-053	BIN: general waste, 50L	3	1	[FQCW-019] size, type and quantity of bins dependent on local waste management policies
FQWS-073	BIN: recycling, commingled, 50L	3	1	[FQCW-062] size, type and quantity of bins dependent on local waste management policies
HYBA-121	BASIN: type B, handwashing	1	1	[HYBA-010]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	1	1	[HYTP-037] to basin
ITAV-121	DISPLAY SCREEN: AV system	3	1	[ITBU-011] optional
ITNE-076	TELEPHONE: handset, wall mounted	2	1	[ITNE-053]



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101.01	GPO: single, wall mounted, horizontal	1	1	[ELGP-109] to meal trolley parking area; power requirements dependent on type of meal trolley
ELGP-201.01	GPO: double, wall mounted, horizontal	1	3	[ELGP-208]
ELGP-201.01	GPO: double, wall mounted, horizontal	1	1	[ELGP-208] optional, to television
ELSW-001	SWITCH: light	1	1	[ELBO-015]
ITCL-121	BUTTON: nurse call, patient to staff call, with cancel, wall mounted	1	2	[ITCL-006] optional, dependent on patient cohort, provide in areas requiring high staff observation; with indicator button and light
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	1	2	[ITCL-008] with indicator button and light
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] with indicator button and light
ITCL-251	HANDSET: nurse call, patient to staff call	1	1	[ITCL-028] optional, dependent on patient cohort, provide in areas requiring high staff observation; with indicator button and light
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	[ITIN-016] to wall mounted telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	[ITIN-026] optional, to television, MATV outlet may also be provided depending on local ICT policies

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).