

Room Name | **Ensuite - Birthing Room**

Room Number: ENS-BR-A

Last modified	01/03/2016
Briefed Area	10.00
Remarks	
Occupancy	1 patient; 1-2 staff assisting
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Sound attenuation level high, Acoustic privacy is required.
Description or Special Requirements	<p>The Birthing Room Ensuite is for the Birthing Room patient to wash, shower, use the toilet, and bath as desired for pain relief, either independently or with assistance. The area and layout must accommodate an assisting nurse. The Ensuite will include a shower, handbasin, toilet and an island bath. The island bath will include steps and a seating platform at the bath edge. Acoustics: Sound attenuation level - High. Acoustic privacy required. Body Protected Electrical Area Additional Design Requirements: - The shower floor must not have a raised hob - The entrance is to be flush with the adjoining flooring - The door is to be fitted with escape hardware</p>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	Tiles also acceptable
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet areas; tiles also acceptable
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9001	Door - 1100mm	Solid Core	Paint	Single leaf	910 clear outward opening, privacy latch, emergency release
7001	Windows				optional, obscure glass
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	or tiles for a tiled floor

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-10800	Hook - for IV flasks	1	3	
FF-13700	Mirror	1	1	over basin
FF-16250	Oxygen flowmeter	3	1	
FF-20650	Soap / shampoo holder	1	1	
FF-2300	Chair - shower	3	1	
FF-23700	Towel rail	1	1	with grab rail strength and fixings
FF-3400	Coathook	1	2	1 @ 1200 AFFL for wheelchair users
FF-4800	Curtain track - shower (90deg)	1	1	
FF-5300	Curtain - shower	3	1	
FF-6152	Dispenser - disposable glove	2	1	

Room Name | Ensuite - Birthing Room

Room Number: ENS-BR-A

AusHFG code	Description	Group	Qty	Comments
FF-6154	Dispenser - paper/ hand towel	2	1	
FF-6156	Dispenser - soap	2	1	
FF-6160	Dispenser - toilet paper	1	1	
FF-8400	Grab rail - WC	1	2	1 behind toilet, 1 to side
FF-8430	Grab rail - Bath	1	1	
FF-8450	Grab rail - Shower	1	1	
FF-8500	Grab rail - WC, hinged	1	1	optional, drop down rail
FF-9200	Hook - for catheter bag	1	3	
FF-5824	Waste bin - general	3	1	to basin

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-B (sim)
FE-3200	Bath - patient	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	island, with steps & seating platform
FE-47400	Shower - hand-held	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	low level over bath
FE-47400	Shower - hand-held	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-55605	Toilet suite - patient	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-40406	Tapware - shower mixer	1	2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6001	General: colour corrected	

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	
S-9040	Body protected	1	1	
S-4000	Hot water: outlet	1	1	to washing machine
S-4010	Cold water: outlet	1	1	to washing machine

Standard Components - Room Data Sheet

Room Name | **Ensuite - Birthing Room**
Room Number: ENS-BR-A

AusHFG code	Description	Group	Qty	Comments
S-4033	Floor waste	1	2	
S-5000	Airconditioning	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	3	+ indicator button & light
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-2072	Scavenge Outlet	1	1	and controls, on wall, optional
S-7000	Oxygen (O2)	1	1	
S-7010	Nitrous Oxide (N2O)	1	1	services panel
S-7070	Scavenge	1	1	services panel
S-11000	Wall panel	2	1	patient services panels