



Ensuite - Birthing

Room Code	ENS-BR
Briefed Area	7.00 m ²
Ceiling Height	2.4 m
Occupancy	1 mother; 1-2 staff / support persons assisting
Hours of Operation	24 hours

Description | An Ensuite - Birthing Room is for a mother to wash, shower and use the toilet, either independently or with assistance. During labour, the shower may be used for extended periods to manage pain and two shower heads are provided to support this.

Electrical | PROTECTION: body protected ☒
PROTECTION: cardiac protected ☐

Lighting | LIGHTING: general ☒
LIGHTING: colour corrected ☐
LIGHTING: dimmable ☐
LIGHTING: indirect ☐

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset ☒

HVAC | AIRCONDITIONING: general ☐
AIRCONDITIONING: HEPA filtered ☐
AIRCONDITIONING: positive pressure ☐
AIRCONDITIONING: negative pressure ☐
VENTILATION: exhaust ☒
VENTILATION: natural ☐

Additional Considerations |

- The area and layout must accommodate an assisting midwife and a support person.
- The Ensuite - Birthing will have direct access from the Birthing Room.
- The shower floor must not have a raised hob and the entrance to the ensuite is to be flush with the adjoining flooring.
- A ladder or other wall mounted supportive fixtures may be included to provide support at various heights and facilitate different postures during active birthing. A birthing woman's entire weight may be supported on this item, therefore the strength of the item and fixings, including in-wall support, to be equivalent to heavy duty grab rails. Item to be suitable for wet area.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-007.01	DOOR: hinged, 1 leaf, 1100 clear opening, solid	[DWSC-011] outward opening, with privacy latch and emergency release
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	DWPR-005] to birthing room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	DWPR-005] to ensuite side



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-113	FLOOR FINISH: vinyl, seamless, non-slip, wet area	[FLVY-009] to be suitable for bare feet; tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-011.07	WALL FINISH: vinyl, full height	[WLWA-019] tiles are also acceptable
CLFS-013	CEILING: flush set, suspended, moisture resistant	[CLFS-009] moisture resistant drop-in ceiling tiles are also acceptable

CODE	DESCRIPTION	COMMENT
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-009]
CLCN-031	CORNICE: square set	[CLCN-008]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006] over basin
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030]
FIDI-281	HOLDER: soap/shampoo, wall mounted	①	1	[FIDI-049]
FIDI-301	DISPENSER: toilet paper, wall mounted	①	1	[FIDI-036]
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026] optional
FIRT-061	TRACK: curtain, shower	①	1	[FIRT-034] optional, dependent on project/service requirements
FIRT-125	GRAB RAIL: toilet, 90 degree	①	1	[FIRT-006]
FIRT-151	GRAB RAIL: shower, straight, horizontal	①	2	[FIRT-003]
FIRT-191	BACK REST: toilet, accessible	①	1	[FIGE-011]
FIRT-206	RAIL: towel, wall mounted	①	1	[FIRT-016] strength and fixings, including in-wall support, to be equivalent to grab rails
FQGE-102	CURTAIN: shower	③	1	[FQGE-011] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin
FQWS-331	BIN: sanitary waste	③	1	[FQCW-037]
HYBA-143	BASIN: type C, handwashing, with integral double shelf	①	1	[HYBA-002]
HYSH-056	SHOWER: hand-held, connection on wall, bracket on vertical wall mounted rail	①	2	[HYTP-020]
HYTP-051	TAPWARE: basin, mixer, fixture mounted	①	1	[HYTP-036] selection of basin and tapware to be coordinated to ensure compatibility
HYTP-251	TAPWARE: shower, mixer	①	2	[HYTP-039]
HYWC-033	TOILET SUITE: patient, accessible	①	1	[HYWC-001] accessible suite to assist with mobility and support during labor
MMMA-117	SUPPORT FIXTURE: birthing, ladder, wall mounted, wet area	②	1	[MMMA-019] optional; strength and fixings, including in-wall support, to be equivalent to heavy duty grab rails



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201.01	GPO: double, wall mounted, horizontal	①	1	[ELGP-208] to be classified as a shaver outlet
ELSW-001	SWITCH: light	①	1	[ELBO-015] located outside room
HYDR-021	DRAIN: floor waste, round	①	2	[HYDR-004]
HYDR-201	DIRECT CONNECTION: wastewater, general	①	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	①	3	1 to basin tapware, 2 to showers
HYTP-453	DIRECT CONNECTION: water, warm	①	3	1 to basin tapware, 2 to showers

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITCL-122	BUTTON: nurse call, patient to staff call, with cancel, wall mounted, wet area	①	2	[ITCL-006] with indicator button and light, IPX4 rating required
ITCL-182	BUTTON: nurse call, staff assist, with cancel, wall mounted, wet area	①	1	[ITCL-008] with indicator button and light, IPX4 rating required
ITCL-192	BUTTON: nurse call, emergency, with cancel, wall mounted, wet area	①	1	[ITCL-004] with indicator button and light, IPX4 rating required



Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	①	1	[MMSP-026]
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	①	1	[MGAS-032]
MGAS-042	OUTLET: oxygen (O2), on services panel	①	1	[MGAS-042]
MGAS-052	OUTLET: scavenge, on services panel	①	1	[MGAS-053]
MGFP-041	FLOWMETER: oxygen	③	1	[MGFP-004]
MGFP-051	ADAPTER: scavenge	③	1	[MMGE-001]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).