

**Room Name** | **Film Processing, Viewing and Reporting**

**Room Number: FPVR**

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	16.00
<b>Remarks</b>	
<b>Occupancy</b>	Up to 4
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 8am to 8pm, daily
<b>Acoustics</b>	Sound attenuation level medium, Acoustic privacy is required.
<b>Description / Special Requirements</b>	A room located within the Medical Imaging Unit to accommodate the film processing equipment along with a workstation area for viewing, and reporting of images. Acoustics: Sound attenuation level - Medium; acoustic privacy required.

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	above sink, tiles also acceptable
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening, glazing optional
7010	Observation	Glass	Clear	Through door/s	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	with inset sink
FF-1120	Bench - workstation	1	1	
FF-17360	Pinboard - fabric covered	1	2	above bench
FF-20000	Shelving unit - adjustable	1	5	over workstation bench
FF-2100	Chair - ergonomic, office	3	2	
FF-21290	Cupboard - steel	3	1	chemical storage
FF-3350	Clock - battery operated	3	1	
FF-4410	Cupboard - under bench	1	1	adjustable shelves
FF-4460	Cupboard - wall mounted	1	1	over sink bench, adjustable shelves
FF-6154	Dispenser - paper/ hand towel	2	1	to sink
FF-6156	Dispenser - soap	2	1	to sink
FF-5824	Waste bin - general	3	1	

## Fixtures, Equipment and associated Services

Room Name | Film Processing, Viewing and Reporting

Room Number: FPVR

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11415	Computer - PACS	3	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	for computerised images
FE-41100	Printer - networked	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-49115	Sink - 600x450x450D	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	hot water, lab sink
FE-54510	Telephone - handset, standard	3	2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-65100	IMG - processor, daylight	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-65900	IMG - silver recovery unit	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-69210	Xray viewer - multiscreen	1	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional
FE-4045	Tapware - elbow mixer	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6005	Dimmable	for image viewing

## Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	6	
S-9060	GPO: Special: for equipment	1	2	TV, ceiling
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-1006	Voice / Data outlet: double	1	4	1 outlet for telephone
S-4037	Tundish drain	1	1	for low temp steriliser, optional
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6005	Dimmable	1	1	for image viewing
S-6200	Light switches	1	1	
S-6200	Light switches (pelmet)	1	1	
S-6055	Special: task light, built in	1	4	under O/H cupboards