



## Interview Room

<b>Room Code</b>	INTV
<b>Briefed Area</b>	12.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	up to 8 persons
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | The Interview Room provides space for confidential discussion and/or counselling between staff, patients and/or family members where required. The Interview Room may also be used as a multipurpose room for small staff groups or discussions.

**Electrical** | PROTECTION: body protected   
PROTECTION: cardiac protected

**HVAC** | AIRCONDITIONING: general   
AIRCONDITIONING: HEPA filtered   
AIRCONDITIONING: positive pressure   
AIRCONDITIONING: negative pressure   
VENTILATION: exhaust   
VENTILATION: natural

**Lighting** | LIGHTING: general   
LIGHTING: colour corrected   
LIGHTING: dimmable   
LIGHTING: indirect

**Nurse Call and Duress** | NURSE CALL SYSTEM: buttons / handset

**Additional Considerations** |

- An external outlook is desirable. Assumes staff will bring their own devices as required.
- A second door may be required for staff safety and security; the location of the second door will be dependent on the availability an appropriate area to egress.
- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005]
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005] optional, for staff egress
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area

CODE	DESCRIPTION	COMMENT
ITSE-261	READER: security, access control, proximity card, wall mounted	[ITSE-038] optional to second egress door
WIFX-057.01	WINDOW: fixed, internal, double glazed, sill at 900H	[DWWH-005]
AHWCV-001	WINDOW COVERING: blind, roller, single	[DWWD-004]



## Finishes

CODE	DESCRIPTION	COMMENT
FLCP-006	FLOOR FINISH: carpet tiles	[FLCP-006]
FLSK-026	SKIRTING: vinyl, feather edge	[FLSK-009] aluminum skirting is also acceptable
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	[FIBM-019]
FQBS-101	CHAIR: visitor, clinical areas	3	4	[FQBS-058]
FQBS-251	ARMCHAIR: visitor, clinical areas	3	1	[FQBS-010]
FQBS-352	LOUNGE: 2 seat	3	1	[FQBS-041]
FQGE-002	ARTWORK: wall mounted	3	1	[FQGE-002] optional
FQTA-202	TABLE: square, 450H, 600L	3	2	[FQTA-075]
ITNE-071	TELEPHONE: handset, desktop	3	1	[ITNE-050]



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	1	1	[ELGP-208]
ELGP-201.01	GPO: double, wall mounted, horizontal	1	2	[ELGP-208]
ELSW-001	SWITCH: light	1	1	[ELBO-015]
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	1	1	[ITCL-008] optional, + indicator button & light
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] optional, + indicator button & light
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	[ITIN-026]
ITSE-061	BUTTON: security, duress, fixed, wall mounted	1	1	[ITSE-006]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).