



Medication Room, 14m2

Room Code	MED-14
Briefed Area	14.00 m ²
Ceiling Height	2.7 m
Occupancy	1-2 staff intermittently
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Medication Room, 14m2 is used for the secure storage of medications, including intravenous fluids, and a small amount of medication-related clean consumables.

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations

- The medication room may provide storage for drugs of dependence in accordance with relevant legislation.
- Controlled temperature and humidity is required for medication storage and internal temperatures should not rise above 25°C.
- Secured staff only access to the room is required.
- The provision and placement of CCTV cameras is dependent on jurisdictional policies.
- Refer to project specific requirements for the provision of automated medication management systems.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-043.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, wide vision panel	[DWGL-003]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area
ITSE-261	READER: security, access control, proximity card, wall mounted	[ITSE-038]



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed

CODE	DESCRIPTION	COMMENT
		equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, covered	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.06	WALL FINISH: vinyl, to 2100 AFFL	[WLWA-023] extent dependent on type and height storage solution
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020] extent dependent on type and height storage solution
CLFS-011	CEILING: flush set, suspended	[CLFS-006]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	1	[FIJO-059]
JOCU-101	CUPBOARD: wall mounted, single door	①	1	[FIJO-157]
JODW-032	DRAWER UNIT: under bench, 3 drawers, equal, wire baskets	①	5	[FIJO-108]
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	1	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-072	DISPENSER: sticker roll, wall mounted	②	1	[FIDI-052] optional
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-111	BRACKET: sharps bin, wall mounted	②	1	[FIHR-016]
FQSM-152	STORAGE SOLUTION: modular system, mobile, 400D x 600W x 2100H nominal	③	3	[FQSM-046] type and quantity of storage options to be determined based on service requirements
FQSM-202	SHELVING UNIT: mobile, adjustable shelves, 400D x 600W x 2100H nominal	③	2	[FQSM-048] type and quantity of storage options to be determined based on service requirements
FQWS-003	BIN: sharps, clinical, medium	③	1	[FQCW-044]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin
FQWS-271	BIN: pharmaceutical waste, 20L	③	1	[FQCW-061]
HYBA-121	BASIN: type B, handwashing	①	1	[HYBA-010]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037]
ITSE-121	CAMERA: security, CCTV, indoor, dome, ceiling mounted	①	1	[ITSE-012] optional, provision and placement dependent on local policies
MMPH-002	SAFE: dangerous drugs, wall mounted, medium	①	1	[MMGE-087] size and quantity to be based on service requirements

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MMPH-024	FRIDGE: medication/vaccine, 1000L nom, double door	3	1	[MMGE-034] size and quantity to be based on service requirements



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-131	GPO: single, emergency power, wall mounted	1	1	[ELGP-123] to drug fridge
ELGP-201	GPO: double, wall mounted	1	2	[ELGP-208]
ELGP-231	GPO: double, emergency power, wall mounted	1	2	[ELGP-223] optional, for future provision of automated dispensing cabinets
ELSW-001	SWITCH: light	1	2	[ELBO-015] 1 x general room lighting, 1 x task light
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	[ITIN-016] to drug fridge, for temperature monitoring
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	[ITIN-026]
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	[ITIN-026] optional, for future provision of automated dispensing cabinets
LIFX-108	LIGHT: task, integral to joinery	1	1	[LIFX-008] under wall mounted joinery

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).