



Meeting Room, 30m²

Room Code	MEET-30
Briefed Area	30.00 m ²
Ceiling Height	2.7 m
Occupancy	up to 18 staff seated
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Meeting Room, 30m² provides the space and amenities to accommodate up to 18 staff (seated) for meetings, education and training activities.

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations

- The configuration of videoconferencing systems and AV equipment will vary to suit service requirements and local ICT policies. The display system, sound system, microphone, camera, control panels and supporting AV equipment must be carefully considered within the context of the department/facility in order to provide a cohesive, intuitive solution for users.
- Where a camera is provided for video conferencing the furniture layout should be considered to allow for visibility of users within the field of view. Decor should also be light/neutral and free from busy patterns within the camera view for optimal image quality.
- Furniture and layout will vary to suit service requirements. Selection of furniture that supports reconfiguration of the layout for flexible use of the space is recommended, e.g. provision of stackable chairs and folding tables.
- Due to the flexibility of furniture arrangements possible within meeting rooms, the occupancy of the room will vary. The total number of people that may be accommodated in the space will be dependent on the furniture layout.
- Floor boxes for services may be provided to support flexible use of the space. Location to be confirmed to suit service requirements.
- The requirement for the inclusion of hearing augmentation systems (e.g. hearing aid induction loops, or solutions that require infrared, radio frequency, or Wi-Fi systems) will be dependent on the specifications/features of the selected ICT/AV equipment and software. Provision of a hearing augmentation system is to be confirmed at project level in consultation with accessibility and ICT experts.
- Inclusion of a fixed duress button may be considered depending on the location of the room within a department. Fixed duress may not be required where the room is planned in an area that is only accessible by staff. Mobile duress coverage is to be assessed and planned at a department level to suit local security and WHS policies and operational service requirements.
- Where a meeting room is intended to be used with patients and/or support persons, carers, family, etc., additional features for staff safety (e.g. duress buttons, additional egress doors, etc.) may be required to suit service requirements and local WHS and security policies. An operational model for responding to calls will be needed to support the inclusion of duress call system.
- When a meeting room is to be used with patients and/or support persons, carers, family, etc. in mental health settings, an alternative egress door should be provided. Where appropriate, equipment may be recessed into walls and finishes, fittings, fixtures and furniture should be suitable for mental health patients. All glazing (including external windows) is to be Grade A safety glass to comply with AS/NZS 2208 and AS 1288. Toughened and laminated glass with a structural interlayer is recommended. Additional requirements for glazing are to be confirmed at project level to suit the specific mental health environment (i.e. non-acute, acute, intensive care).
- Room booking panels may be provided to suit the department/facility approach to room scheduling.
- Acoustics are to be carefully considered to ensure appropriate sound levels and to reduce noise transfer to/from adjacent areas for privacy and to reduce disruption, particularly where videoconferencing equipment is provided. Background noise (e.g. from air

conditioning) should be minimised. Some hard surfaces may be covered with appropriate acoustic finishes to reduce reverberation as required.

- Ready access to a telephone in an adjacent space may be required for staff to answer pagers.
- Access to natural light is desirable and, where overall department planning allows, an external window should be provided.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005] may be lockable
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to corridor side, extent dependent on equipment movement in adjacent area
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
WIFX-156.01	WINDOW: fixed, external, double glazed, sill at 750H	[DWWH-005] access to natural light is desirable
AHWCV-001	WINDOW COVERING: blind, roller, single	[DWWD-004]



Finishes

CODE	DESCRIPTION	COMMENT
FLCP-006	FLOOR FINISH: carpet tiles	[FLCP-006]
FLSK-026	SKIRTING: vinyl, feather edge	[FLSK-009] aluminum skirting is also acceptable
WLFI-202	ACOUSTIC TREATMENT: wall panel, prefinished	[WLWA-001] optional; to suit acoustic requirements
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-001	BENCH: 450D, laminate	①	1	[FIJO-011]
JOBE-211	BENCH SUPPORT: bracket	①	2	[FIHR-065]
JOBE-251	CAP: cable access	①	1	[FIJO-099]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	②	1	[FIBM-019]
FIHR-331	BRACKET: display screen, single, fixed, wall mounted	②	1	[FIHR-006] configuration of ICT/AV equipment to suit service requirements and local ICT policies
FQBS-142	CHAIR: meeting room, stackable	③	18	[FQBS-059]
FQGE-121	CLOCK: analogue display, battery operated	③	1	[FQGE-005]
FQTA-126.04	TABLE: rectangular, 750H, 1500L x 900W, folding, on casters	③	3	[FQTA-086] 2 with services boxes to connect to floor boxes
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITAV-102	CONTROL PANEL: AV system, wall mounted	①	1	[ITAV-006] configuration of ICT/AV equipment to suit service requirements and local ICT policies; item may be wall mounted, table mounted or portable
ITAV-111	COMPUTER: AV system, central processing unit (CPU)	③	1	[ITAV-063] configuration of ICT/AV equipment to suit service requirements and local ICT policies
ITAV-121	DISPLAY SCREEN: AV system	③	1	[ITAV-051] configuration of ICT/AV equipment to suit service requirements and local ICT policies
ITAV-132	CAMERA: AV system, video conferencing, wall mounted	①	1	[ITNE-004] multidirectional, configuration of ICT/AV equipment to suit service requirements and local ICT policies
ITAV-142	MICROPHONE: AV system, ceiling mounted, array	①	1	[ITAV-071] may be recessed in ceiling, configuration of ICT/AV equipment to suit service requirements and local ICT policies
ITAV-152	SPEAKER: AV system, ceiling recessed	①	4	[ITAV-057] configuration of ICT/AV equipment to suit service requirements and local ICT policies
ITBU-031	CONTROL PANEL: room booking system	①	1	[ITAV-062] optional, provision to suit service requirements and local ICT policies



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-105	GPO: single, wall mounted, cleaner	①	1	[ELGP-110] as required for distribution across the unit in accordance with AS/NZS 3003
ELGP-126	GPO: single, in floor box	①	4	[ELGP-103]
ELGP-201	GPO: double, wall mounted	①	3	[ELGP-208] to AV/videoconferencing equipment; quantity to be confirmed to suit equipment selection and service requirements
ELGP-201	GPO: double, wall mounted	①	1	[ELGP-208]
ELSW-001	SWITCH: light	①	1	[ELBO-015]
ITIN-016	OUTLET: data, single RJ45, wall mounted	①	1	[ITIN-016] optional, to room booking control panel if provided
ITIN-016	OUTLET: data, single RJ45, wall mounted	①	1	[ITIN-016] to AV system control panel
ITIN-021	OUTLET: data, double RJ45, ceiling mounted	①	1	[ITIN-021] to microphone array
ITIN-022	OUTLET: data, double RJ45, in floor box	①	2	[ITIN-022]
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	1	[ITIN-026]
ITIN-036	OUTLET: data, triple RJ45, wall mounted	①	2	[ITIN-036] to AV/videoconferencing equipment; AV outlet type and quantity to be confirmed to suit equipment selection and service requirements
ITIN-162	FLOOR BOX: power and data outlets, flush floor mounted	①	2	[ITIN-143]
ITIN-172	DESK BOX: power and data outlets, softwired, flush mounted	①	2	[ITIN-145] softwired for connection to floor box or wall mounted services

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).