



Mortuary - Body Holding

Room Code	MOR-BH
Briefed Area	22.00 m²
Ceiling Height	2.7 m
Occupancy	1-2 staff intermittently
Hours of Operation	24 hours

Description	The Mortuary - Body Holding provides refrigerated storage for the temporary holding of bodies with an adjacent area to transfer a body from a trolley into storage.				
Electrical	PROTECTION: body protected	☐	HVAC	AIRCONDITIONING: general	☐
	PROTECTION: cardiac protected	☐		AIRCONDITIONING: HEPA filtered	☐
Lighting	LIGHTING: general	☒		AIRCONDITIONING: positive pressure	☐
	LIGHTING: colour corrected	☐		AIRCONDITIONING: negative pressure	☒
	LIGHTING: dimmable	☐		VENTILATION: exhaust	☐
	LIGHTING: indirect	☐		VENTILATION: natural	☐
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	☐			
Additional Considerations	• The room can be configured with refrigerated cabinets or as a cool room depending on service requirements. • The Mortuary - Body Holding should be located with ready access to the Mortuary - Viewing Room.				

Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel	[DWGL-033]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area

Finishes

CODE	DESCRIPTION	COMMENT
FLVY-112	FLOOR FINISH: vinyl, seamless, non-slip, safety	[FLVY-004]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.03	WALL FINISH: vinyl, to 1200 AFFL	[WLWA-025]
CLFS-011	CEILING: flush set, suspended	[CLFS-006]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]

CODE	DESCRIPTION	COMMENT
CLCN-031	CORNICE: square set	[CLCN-008]
WLPR-006	WALL PROTECTION: corner guards	[WLPR-006]
WLPR-046.03	WALL PROTECTION: crash rail, to 900 AFFL	[WLPR-021]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	2	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	2	1	[FIDI-025] to basin
FIDI-256	DISPENSER: soap, wall mounted	2	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	2	1	[FIDI-031] to basin
FIHR-029	HOOK: equipment, wall mounted	1	1	[FIHR-029] for lifter straps/slings
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016] to basin
HYBA-121	BASIN: type B, handwashing	1	1	[HYBA-010]
HYGE-151	HOSE REEL: retractable	1	1	[HYTP-003]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	1	1	[HYTP-037]
HYTP-421	TAPWARE: hosecock, wall mounted	1	1	[HYTP-012]
MMBE-211	TRACK: patient lifter, fixed, ceiling mounted	1	1	[MMBE-071] mobile lifter may be used, bariatric capacity to be confirmed based on service requirements
MMBE-251	CASSETTE MOTOR: patient lifter, for ceiling mounted system	1	1	[MMBE-070] mobile lifter may be used, bariatric capacity to be confirmed based on service requirements; control may be suspended from motor or wall mounted depending on model
MMBE-266	SLING: patient lifter, supine	3	1	[MMBE-070] mobile lifter may be used, bariatric capacity to be confirmed based on service requirements; control may be suspended from motor or wall mounted depending on model
MMMT-026	TROLLEY: mortuary, hydraulic stacking	3	1	[MMGE-133] bariatric capacity to be confirmed based on service requirements
MMMT-054	FRIDGE: body holding, 3 tier	2	3	[MMGE-183] bariatric capacity to be confirmed based on service requirements; power and BMS requirements to be confirmed by project



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-105	GPO: single, wall mounted, cleaner	1	1	[ELGP-110] IP rated to suit AS/NZS wet zone requirements
ELGP-106	GPO: single, ceiling mounted	1	1	[ELGP-101] to lifter
ELGP-191	GPO: single, special, for equipment, wall mounted	1	3	[ELGP-106] 1 to each refrigerator; required to be emergency power/generator backed. IP rated to suit AS/NZS wet zone requirements
ELSW-001	SWITCH: light	1	1	[ELBO-015] IP rated to suit AS/NZS wet zone requirements
HYDR-021	DRAIN: floor waste, round	1	1	[HYDR-004]
HYTP-451	DIRECT CONNECTION: water, cold	1	1	to hosecock

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITBU-401	ALARM: equipment monitoring, temperature	1	1	[ITBU-001] temperature monitoring, alarm and BMS requirements to be confirmed by project
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	3	[ITIN-016] temperature monitoring, IP rated to suit AS/NZS wet zone requirements, 1 to each refrigerator, BMS requirements to be confirmed by project

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).