



Mortuary - Body Reception

Room Code	MOR-BR
Briefed Area	7.00 m ²
Ceiling Height	2.7 m
Occupancy	1-2 staff intermittently
Hours of Operation	Up to 24 hours

Description | The Mortuary - Body Reception is an area for receiving bodies from the hospital and checking-in to the holding room/cool room as well as the checking-out of bodies for release to funeral directors, relatives or for transfer to the coroner.

Electrical	PROTECTION: body protected	☐	HVAC	AIRCONDITIONING: general	☒
	PROTECTION: cardiac protected	☐		AIRCONDITIONING: HEPA filtered	☐
Lighting	LIGHTING: general	☒		AIRCONDITIONING: positive pressure	☐
	LIGHTING: colour corrected	☐		AIRCONDITIONING: negative pressure	☐
	LIGHTING: dimmable	☐		VENTILATION: exhaust	☐
	LIGHTING: indirect	☐		VENTILATION: natural	☐
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	☐			

Additional Considerations | • This room should be located on a corridor that is in close proximity to both the staff-only mortuary entry and the exit to the funeral director's covered parking area. Entry to this area by authorised personnel only. Handwashing facilities should be located in close proximity.



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLTI-021.02	CEILING: drop-in tiles, prefinished, 600 x 1200	[CLTI-008]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	2	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	[FIBM-019]
FIDI-101	DISPENSER: PPE, disposable masks, wall mounted	2	1	[FIDI-021]
FIDI-111	DISPENSER: PPE, disposable gowns/aprons, wall mounted	2	1	[FIDI-018]
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	2	1	[FIDI-001]
FQBS-171	CHAIR: office, ergonomic	3	1	[FQBS-018]
FQDW-134.09	WORKSTATION: straight, adjustable height, 720H nom, 750D x 2400W	3	1	[FQDW-045] length to accommodate A3 landscape mortuary register
ITNE-071	TELEPHONE: handset, desktop	3	1	[ITNE-049]
ITNE-101	COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop	3	1	[ITNE-007]
ITNE-311	PRINTER: desktop	3	1	[ITNE-023]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	1	3	[ELGP-208] emergency power may be provided depending on operational policies and service requirements
ELSW-001	SWITCH: light	1	1	[ELBO-015] for task lighting
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	[ITIN-026] 1 outlet for telephone
LIFX-108	LIGHT: task, integral to joinery	1	2	[LIFX-008] to underside of overhead cupboards

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).