



## Mortuary - Viewing Room

<b>Room Code</b>	MOR-VR
<b>Briefed Area</b>	8.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	up to 5 visitors; 1-2 staff
<b>Hours of Operation</b>	8am to 5pm, daily (may vary depending on services requirements)

**Description** | The Mortuary - Viewing Room is provided for relatives and others to view a body with the support of a social worker. The Mortuary - Viewing Room will be located adjacent to the Mortuary - Waiting.

<b>Electrical</b>	PROTECTION: body protected	<input type="checkbox"/>	<b>HVAC</b>	AIRCONDITIONING: general	<input type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input checked="" type="checkbox"/>	
	LIGHTING: dimmable	<input checked="" type="checkbox"/>	VENTILATION: exhaust	<input type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input type="checkbox"/>	
<b>Nurse Call and Duress</b>	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>			

**Additional Considerations** | • A body may be viewed through a window from within the Mortuary - Waiting, with access provided between the two rooms provided to allow for viewing a body directly.



### Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-212.01	DOOR: hinged, 2 leaves, 1600 clear opening, solid, standard vision panel	[DWGL-052] to corridor
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-003] to viewing room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] to waiting room
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-003] to viewing room side
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-003] to waiting room side
WIFX-006.01	WINDOW: fixed, internal, single glazed, sill at 750H	[DWOB-005]



### Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLFS-011	CEILING: flush set, suspended	[CLFS-006]

CODE	DESCRIPTION	COMMENT
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	2	1	[FIDI-001]
FIRT-051	TRACK: curtain, privacy	1	1	[FIRT-031]
FQGE-101	CURTAIN: privacy screen	3	1	[FQGE-010] heavy/domestic fabric is acceptable
MMMT-021	TROLLEY: mortuary, transport, concealment	3	1	[MMGE-186]



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELSW-001	SWITCH: light	1	1	[ELBO-015]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).