

Room Name | Mortuary - Waiting

Room Number: MOR-W

Last modified 01/03/2016

Briefed Area 9.00

Remarks

Occupancy

Up to 4

Hours of Operation

☒ 24 Hours

Acoustics

Description or Special Requirements

The Mortuary Waiting provides an area for relatives and other personnel to await the viewing of a body. The area should be comfortable and non-clinical in appearance. The Viewing Room will be located adjacent to the Waiting Room.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	to basin area
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin, tiles also acceptable
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	plasterboard drop in tile ceiling also acceptable
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	910mm clear opening, lockable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-12750	Lounge - 2 seat	3	1	
FF-22800	Table - low	3	1	
FF-2655	Chair - visitor	3	3	
FF-350	Artwork	3	1	optional
FF-530	Basin vanity top	1	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-5824	Waste bin - general	3	1	to basin

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2850	Basin - handwash, Type C (with vanity)	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-54520	Telephone - handset, handsfree (WM)	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Room Name | Mortuary - Waiting

Room Number: MOR-W

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6046	Indirect lighting	optional

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	
S-6046	Indirect lighting	1	1	optional
S-10005	Duress alarm	1	1	